

PART 1 General

1.1 CONTRACT DOCUMENTS

- .1 This Addendum forms an integral part of the Contract Documents, describing all aspects of the Work and is to be read in conjunction herewith. This document is to be read in conjunction with the drawings and specifications and shall be recognized as a Contract Document. If points arise which are at variance, this Addendum shall take precedence, unless otherwise clarified by the Architect. This Addendum shall be returned with the other bid documents

1.2 ACKNOWLEDGEMENT

- .1 The Bidder is responsible for signifying they have received this Addendum by listing the Addendum number and date in the appropriate space on the Tender Form.

PART 2 ARCHITECTURAL

2.1 Specifications:

- .1 Section 09 65 16 Resilient Sheet Flooring
 - .1 **Delete:** article 2.1.3 in its entirety.
 - .2 Primer and waterproofing for the slab on grade is
 - .1 Tec Multipurpose Primer 560
 - .2 Tec LiquiDam Penetrating Moisture Vapor Barrier 213.
- .2 Section 12 35 53.13 Steel Laboratory Casework
 - .1 **Add:** to end of article 2.1.5, acceptable equivalent
 - .1 CIF Lab Solutions
 - .2 Mott Lab.

2.2 Drawings

- .1 A210 New Construction Floor Plan Reflected Ceiling Plan
 - .1 Drawing Notes, note no.9
 - .1 **Delete:** note in it is entirety.
 - .2 **Add:** Prepare floor surface for flooring with primer and moisture vapour barrier membrane. For floor preparation refer to flooring manufacture for recommendations.

END OF DOCUMENT