

Part 1 ADDENDUM NO.1

1.1 General

- .1 This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2 In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

Part 2 Questions

2.1 What is meant by prepainted on interior face of the cladding as noted below and highlighted in yellow.

This means that the interior of the panel cannot be un-finished raw metal.

2.2 Also what 2 colours will be used as the standard colour range for 22 Gauge 7/8” Corrugated is very limited. If you also check the specs for the flashings, it reads the same, so I will need this clarified as well.

The colors would be a light to mid grey as a primary color with a dark grey/ dark red or blue on the trim.

2.3 The Spec calls for 2 sided paint on this one. Since the interior face will not be exposed? Is this needed? If so I will need to request special pricing for 2 sided coil which may come at a min. buy premium for the painting. Also the supplier no longer carry's the Weather X paint system so this would have to be Weather XL.

Two sided paint is not required. Weather XL is acceptable.

END OF SECTION