



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
Pacific Region  
401 - 1230 Government Street  
Victoria, B.C.  
V8W 3X4  
Bid Fax: (250) 363-3344

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
401 - 1230 Government Street  
Victoria, B. C.  
V8W 3X4

<b>Title - Sujet</b> Fuel Oil Purifiers	
<b>Solicitation No. - N° de l'invitation</b> F1782-17C828/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> F1782-17C828	<b>Date</b> 2017-09-29
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$XLV-211-7299	
<b>File No. - N° de dossier</b> XLV-7-40055 (211)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-10-10</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> Specified Herein - Précisé dans les présentes <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input checked="" type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Buchan, Torrey	<b>Buyer Id - Id de l'acheteur</b> xlv211
<b>Telephone No. - N° de téléphone</b> (250) 216-2092 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
F1782-17C828/A  
Client Ref. No. - N° de réf. du client  
F1782-17C828

Amd. No. - N° de la modif.  
002  
File No. - N° du dossier  
XLV-7-40055

Buyer ID - Id de l'acheteur  
xlv211  
CCC No./N° CCC - FMS No./N° VME

This solicitation amendment is hereby issued to address questions posed by industry and extend the bidding period.

No.	Question	Answer
1	I read that the system needs to be able to keep up with the generator as the existing is failing to keep up. Does this mean that it will be transferring fuel to the generator through the fuel polisher?	No, the FOP will be transferring the fuel from the storage tanks to the Day tank.
2	How critical are the RO certification requirements?	This requirement is mandatory.
3	C.12 states "The FOP must require Manual bowl cleaning, No automatic Discharge." Does this refer to water draining? What is the biggest concern, water or particulate?	This means that it does not have an automatic sludge discharge cycle, this is mainly due to the size requirement. The bowl is a one piece unit that is manually cleaned.

The terms and conditions of the solicitation remain the same.