



Parks Canada  
Parcs Canada



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada  
National Contracting Services**

**3, passage du Chien-d'Or  
Quebec, QC  
G1R 3Z8**

INVITATION TO TENDER  
APPEL D'OFFRES

## **AMENDMENT #3 TO:**

### **Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

### **Soumission à: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

### **Comments – Commentaires**

### **Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### **Issuing Office - Bureau de distribution**

Parks Canada Agency  
3, passage du Chien-d'Or  
Quebec, QC, G1R 3Z8

Title-Sujet <b>POONAMALIE LOCK 32 HERITAGE STONE MASONRY REPAIRS – RIDEAU CANAL NHS</b>		Date <b>2017.09.29</b>
Solicitation No. - No. de l'invitation <b>5P201-17-5163/A</b>	Client Ref. No. – No. de réf du client.	
GETS Reference No. – No de reference de SEAG		
Solicitation Closes L'invitation prend fin –  <b>at – à 2:00 PM on – le 2017-10-05</b>	Time Zone Fuseau horaire - <b>EASTERN DAYLIGHT TIME (EDT)</b>	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à :  Sylvie Lagacé <a href="mailto:sylvie.lagace@pc.gc.ca">sylvie.lagace@pc.gc.ca</a>		
Telephone No. - No de téléphone  <b>418-648-5006</b>	Fax No. – No de FAX:  <b>418-649-6971</b>	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:  <b>See herein</b>		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur  Telephone No. - No de telephone: _____ Facsimile No. - N° de télécopieur: _____		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur  _____ Name / Nom Title / Titre  _____ Signature Date		



## **AMENDMENT #3**

The purpose of this amendment is to share an answer to a question asked by a potential bidder.

*You must consider the information in the evaluation of your bid.*

### **QUESTION AND ANSWER:**

Question #4: According to the specifications the lock walls are made up of sandstone. Our stone supplier from St. Canut Quarry tells that it is not possible to finish exposed faces and edges of St-Canut sandstone to comply with requirements indicated on drawings (bush hammer & light media blast). Is it possible to review the stone finish or to replace St-Canut sandstone by Deschambeau Limestone?

Answer #4: The lock is primarily sandstone. Deteriorated sandstone is to be replaced with sandstone. Media blasting is not required for replacement sandstone. Mock up of the finish is required. If limestone is discovered on site, a mock up with media blasting is required. See drawing S05.

END OF SECTION.

**No change to the tender closing date.**

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.**