



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

BID RECEIVING UNIT

Parks Canada Agency
John Cabot Building,
10 Barter's Hill, 5th Floor
St. John's, NL A1C 6M1

Attention: **Colleen Sheehan**

AMENDMENT 2

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

John Cabot Building,
10 Barter's Hill, 5th Floor
St. John's, NL A1C 6M1

Title-Sujet Barrier Beach Re-nourishment & Groyne Construction, Fortress Of Louisbourg National Historic Site, NS – Parks Canada		Date 2017-09-29
Solicitation No. - No. de l'invitation 5P300-17-5437	Client Ref. No. – No. de réf du client.	
GETS Reference No. – No de reference de SEAG		
Solicitation Closes L'invitation prend fin – at – à 02:00 PM on – le 2017-10-04	Time Zone Fuseau horaire - AT	
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Colleen Sheehan		
Telephone No. - No de téléphone (709) 772-6129	Fax No. – No de FAX: (709) 772-3651	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature	Date	

Amendment #2

Please delete the **Appendix 1 - COMBINED PRICE FORM (2 pages)** and replace with the following:

REVISED APPENDIX 1 - COMBINED PRICE FORM (2 pages)

- 1) The prices per unit shall govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

LUMP SUM

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

(a) Work included in the Lump Sum Amount represents all work not included in the unit price table.

	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity	Estimated Total Price HST extra
1	01 21 00	Allowances	Lump Sum	1	\$80,000.00
2		Supply and Install 500m2 of Geotextile	Lump Sum	1	\$
3		All items Not Included in the Unit Price Table	Lump Sum	1	\$
LUMP SUM AMOUNT (TLSA) Excluding applicable tax(es)					\$

UNIT PRICE TABLE

The Unit Price Table designates Work to which a Unit Price Arrangement applies.

- (a) Work included in each item is as described in the referenced specification section.
- (b) The Price per Unit shall not include any amounts for Work that is not included in that unit price Item.

	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity (EQ)	Price per Unit applicable tax(s) extra (PU)	Extended amount (EQ x PU) applicable tax(s) extra
1	31 05 16	Aggregate Materials	m ³	200	\$	\$
2	31 23 33	Excavation, Trenching, and Backfilling (Beach Excavation)	m ³	2 300	\$	\$
3	35 31 19	Beach Fill (0-150mm)	m ³	43 500	\$	\$
4	35 31 23	Groynes (A1 Armour 3.0-6.0 tonne)	Tonne	4 000	\$	\$
5	35 31 23	Groynes (A2 Armour 1.5-3.0 tonne)	Tonne	3 000	\$	\$
6	35 31 23	Groynes (Core Fill 80-400kg)	Tonne	8 850	\$	\$
7	35 31 23	Groynes (Bedding Layer 1-75kg)	Tonne	1 850	\$	\$
TOTAL EXTENDED AMOUNT (TEA)						
Excluding applicable tax(s)						

TOTAL BID AMOUNT (TLSA +TEA)	
Excluding applicable tax(s)	

Question & Answers

Q1. Can you please comment on the extent to geotextile required. I see it noted on Drawing C-3 section 04, shoreline revetment. I do not see it called up in any other cross section.

It is not clear where the geotextile is required.

A1. It is for the revetment slope and also underneath the aggregate material on the beach itself. (see revised Annex 1. Item 2. Lump Sum Table.