

MECHANICAL EQUIPMENT SCHEDULE																						
EQUIPMENT			ELECTRICAL CHARACTERISTICS			PACKAGED UNIT	STARTER				CONTROLS				FIRE ALARM SHUTDOWN	DRIVE ISOLATION TRANSFORMER	CIRCUITRY INFORMATION				NOTES	
ITEM	DESCRIPTION	LOCATION	HP/kw	AMPS	VOLTS/ø		TYPE	HOA	PILOT LIGHT	PUSH BUTTON	SUPPLIED BY	TYPE	SUPPLIED BY	INSTALLED BY			WIRED BY	PANEL--CCT #	O.C.P.	WIRE		CONDUIT
AHU--09	AIR HANDLING UNIT SUPPLY FAN	PENTHOUSE	7.5 HP	9.0	600/3ø	X	VFD				MECHANICAL				ELECTRICAL	X	40kVA	CDP--900 LOCATED IN BASEMENT ELECTRICAL ROOM. REFER TO NOTE #10.	90A--3P	3--1/C #4AWG TECK90 Cu.	-	PROVIDE SEPARATE 15A, 120V/1ø CIRCUIT FOR AIR HANDLING UNIT LIGHTS AND PLUGS. WIRE AND CONNECT TO PANEL 'PB'.
	AIR HANDLING UNIT SUPPLY FAN	PENTHOUSE	7.5 HP	9.0	600/3ø																	
	AIR HANDLING UNIT SUPPLY FAN	PENTHOUSE	7.5 HP	9.0	600/3ø																	
	AIR HANDLING UNIT SUPPLY FAN	PENTHOUSE	7.5 HP	9.0	600/3ø																	
AHU--13	AIR HANDLING UNIT EXHAUST FAN	PENTHOUSE	7.5 HP	9.0	600/3ø	X	VFD				MECHANICAL				ELECTRICAL	X	40kVA	CDP--400 LOCATED IN ROOM 283. REFER TO NOTE #11.	90A--3P	3--1/C #4AWG TECK90 Cu.	-	PROVIDE SEPARATE 15A, 120V/1ø CIRCUIT FOR AIR HANDLING UNIT LIGHTS AND PLUGS. WIRE AND CONNECT TO PANEL 'PB'.
	AIR HANDLING UNIT EXHAUST FAN	PENTHOUSE	7.5 HP	9.0	600/3ø																	
	AIR HANDLING UNIT EXHAUST FAN	PENTHOUSE	7.5 HP	9.0	600/3ø																	
	AIR HANDLING UNIT EXHAUST FAN	PENTHOUSE	7.5 HP	9.0	600/3ø																	

**NOTES:**

- DIVISION 26 SHALL REFER TO MECHANICAL DRAWINGS FOR EXACT MOTOR LOCATIONS. CONFIRM ACTUAL EQUIPMENT RATINGS, SIZES AND LOCATIONS PRIOR TO ROUGHING--IN OF WIRING AND CIRCUIT BREAKERS. SIZE OVERLOADS ACCORDINGLY. REPORT ANY DISCREPANCIES OR SUBSTITUTIONS TO DEPARTMENTAL REPRESENTATIVE PRIOR TO WIRING INSTALLATION AND CONNECTIONS. (REFER TO ACTUAL EQUIPMENT NAMEPLATES.)
- ALL CONTROL WIRING FOR MECHANICAL ITEMS SHALL BE PROVIDED BY DIVISION 23 UNLESS OTHERWISE. REFER TO MECHANICAL SPECIFICATIONS.
- ALL STARTERS TO BE SUPPLIED AND INSTALLED BY DIVISION 26 UNLESS OTHERWISE NOTED.
- PROVIDE DISCONNECT SWITCHES FOR EQUIPMENT AS REQUIRED BY CODE.
- PROVIDE 120V, 15A CIRCUIT FOR EACH DDC PANEL. REFER TO MECHANICAL DRAWINGS FOR QUANTITY AND LOCATION.
- RE--WIRE AND RE--CONNECT AIR HANDLING UNIT INTERNAL POWER CONNECTIONS AS A RESULT OF DISASSEMBLY DURING SHIPPING.
- PROVIDE SEPARATE DRIVE ISOLATION TRANSFORMER FOR EACH VFD. VFD'S ARE SUPPLIED AND INSTALLED BY DIVISION 23. LINE VOLTAGE WIRED AND CONNECTED BY DIVISION 26. INSTALL DRIVE ISOLATION TRANSFORMER ADJACENT TO VFD, CONFIRM LOCATION WITH DIVISION 23 PRIOR TO ROUGHING--IN. PROVIDE ALL NECESSARY MOUNTING HARDWARE AS REQUIRED.
- ALL MOTORS USING VFD'S TO BE WIRED WITH VFD (VARIABLE FREQUENCY DRIVE) CABLE. INSTALL DRIVE CABLE FROM VFD TO MOTOR ONLY.
- ALL MOTOR DISCONNECT SWITCHES SERVING MOTORS WITH VFD'S TO BE INTERLOCKED TO PROVIDE CONTROLLED SHUTDOWN OF VFD WHEN DISCONNECT SWITCH IS SHUT OFF.
- WIRE AND CONNECT NEW AHU--9 TO EXISTING CDP--900 LOCATED IN BASEMENT MAIN ELECTRICAL ROOM USING 3--1/C#4AWG TECK90 Cu. SUPPLY AND INSTALL NEW 90A--3P CIRCUIT BREAKER IN CDP. EXISTING 70A--3P CIRCUIT BREAKER TO REMAIN AS FUTURE SPARE. CONFIRM FINAL ROUTING OF WIRING ON SITE WITH DEPARTMENTAL REPRESENTATIVE. NEW CIRCUIT BREAKER TO MATCH EXISTING CDP INTERRUPTING CAPACITY. CONFIRM EXISTING ON SITE.
- WIRE AND CONNECT NEW AHU--13 TO EXISTING CDP--400 LOCATED IN ROOM 283 USING 3--1/C#4AWG TECK90 Cu. SUPPLY AND INSTALL NEW 90A--3P CIRCUIT BREAKER IN CDP. EXISTING 50A--3P CIRCUIT BREAKER IN EXISTING MCC#3 TO REMAIN AS FUTURE SPARE. NEW CIRCUIT BREAKER TO MATCH EXISTING CDP INTERRUPTING CAPACITY. CONFIRM EXISTING ON SITE.


**LEGEND:**

**STARTERS**  
MAG = MAGNETIC STARTER  
VFD = VARIABLE FREQUENCY DRIVE  
MAN = MANUAL STARTER  
TOG = MOTOR RATED TOGGLE SWITCH  
CON = CONTACTOR  
HOA = HAND--OFF--AUTO


**CONTROLS**  
T'STAT. = THERMOSTAT  
H'STAT. = HUMIDISTAT  
EMCS = ENERGY MANAGEMENT CONTROL SYSTEM  
TC = TIME CLOCK  
MT = MANUAL TIMER  
MS = MANUAL SWITCH  
VSC = VARIABLE SPEED CONTROLLER  
APS = AIR PROVING SWITCH  
COD =CARBON MONOXIDE DETECTOR  
FA = FIRE ALARM INTERLOCK  
AUTO =INTEGRAL AUTO SWITCH ACTIVATION  
FLOAT =FLOAT SWITCH

**FIRE ALARM SHUTDOWN**  
INTERLOCK SMOKE DUCT DETECTOR TO FIRE ALARM PANEL AND POWER OFF MECHANICAL EQUIPMENT FOR SHUTDOWN. DUCT DETECTOR AND SHUTDOWN ON SEPARATE ZONE

PANELBOARD DIRECTORY 'EXISTING PANEL SBC'						
ITEM	LOAD (kW)	OCB	C	ITEM	LOAD	OCB
EXISTING BREAKER TO REMAIN AS FUTURE SPARE		40A 3P	1	2 ROW 1 SPOTS AND STRIPS	0.88	15A
			3	4 ROW 2+4 STRIPS	0.864	15A
			5	6 ROW 3 SPOTS AND STRIPS	0.88	15A
EXISTING BREAKER TO REMAIN AS FUTURE SPARE		40A 3P	7	8 ROW 5 SPOTS AND STRIPS	0.88	15A
			9	10 ROW 6 STRIPS	0.432	15A
			11	12 ROW 7 SPOTS AND STRIPS	0.88	15A
CONTROL ROOM/FIRING LINE LTS	0.597	15A	13	14 EBB–1	0.07	15A
EBB–2	0.07	15A	15	16 EBB–3	0.07	15A
LANE 1	1.5	20A	17	18 LANE 2	1.5	20A
LANE 3	1.5	20A	19	20 LANE 4	1.5	20A
LANE 5	1.5	20A	21	22 LANE 6	1.5	20A
REC'S (x4)	0.8	15A	23	24 TARGETING CONTROL DESK	1.0	15A
TARGETING SYSTEM PANEL	1.0	15A	25	26 LIGHTING CONTROL PANEL	1.0	15A
			27	28		
			29	30		
			31	32		
			33	34		
			35	36		
			37	38		
			39	40		
			41	42		
NOTES: 1. EXISTING 15A–1P CIRCUIT BREAKERS NO LONGER REQUIRED TO BE REUSED FOR NEW LOADS 2. EXISTING 40A–3P CIRCUIT BREAKERS NO LONGER REQUIRED TO REMAIN AS FUTURE SPARE.				MOUNTING: SURFACE RATING: 225A, 120/208V/3ø/4W		



Public Works and Government Services Canada




Travaux publics et Services gouvernementaux Canada


REAL PROPERTY SERVICES  
Western Region

SERVICES IMMOBILIERS  
Région de l'ouest


PRELIMINARY  
NOT FOR CONSTRUCTION



HDK CONSULTING INCORPORATED  
55-81 Garry St.  
Winnipeg, Manitoba  
Canada, R3C 4J9  
T: 204.616.0380  
F: 204.616.0388  
www.hdkconsulting.com  
info@hdkconsulting.com



Certificate of Authorization  
HDK Consulting Incorporated  
No. 5539 Date: 04/30/2015



5		
4		
3		
2	ISSUED FOR CONSTRUCTION	FEB 23/15
1	ISSUED FOR 99% REVIEW	DEC 22/14
0	ISSUED FOR 50% REVIEW	OCT 20/14
Revision	Description	Date

Client client

ROYAL CANADIAN MOUNTED POLICE  
D-DIVISION

1091 PORTAGE AVENUE  
WINNIPEG, MANITOBA

Project

WINNIPEG, MANITOBA  
1091 PORTAGE AVENUE  
D-DIVISION HEADQUARTERS

FIRING RANGE UPGRADE

Project

Designed by  
HUGO CEA CANAS / PAUL LAPOINTE

Conçu par

Drawn by  
PAUL LAPOINTE

Dessiné par

Approved by  
HUGO CEA CANAS

Approuvé par

PWGSC Project Manager  
PAUL DUCHARME

Administrateur de Projets TPSCG

Drawing title  
ELECTRICAL SCHEDULES

Titre du dessin

Project no./No. du projet

Drawing no./No. du dessin  
E2.3  
OF XX

Revision no.  
0