



SYMBOL SCHEDULE	
D	EXISTING DEVICE TO BE DEMOLISHED
E	EXISTING DEVICE TO REMAIN
SW	LOW VOLTAGE WALL SWITCH
GR	GRAPHIC TOUCHSCREEN DISPLAY
R	120V 4 PLEX RECEPTACLE
D	120V DUPLEX RECEPTACLE
	- U/C - UNDER COUNTER
	- TL - TWIST LOCK
EL	2 LAMP EMERGENCY LIGHTING HEAD
EL	EMERGENCY LIGHTING BATTERY BANK C/W 2 EMERGENCY LIGHTING HEADS
VO	VOICE/DATA OUTLET
ES	SINGLE SIDED RED EXIT SIGN
CR	CEILING MOUNTED RECEPTACLE
RD	RECESSED DOWNLIGHT
SP	SPEAKER
TS	TARGETING SYSTEM INTERFACE
PA	PUBLIC ADDRESS HORN
FB	FIRE ALARM BELL
FS	FIRE ALARM STROBE
JB	JUNCTION BOX
SD	DUCT SMOKE DETECTOR
MC	MOTOR CONNECTION C/W DISCONNECT
YS	YOKE MOUNTED SPOT LIGHT
SS	SURFACE MOUNTED STRIP
Z	ZONE
PP	POWER PACK
L	LUMINAIRE RECESSED IN T-BAR
B	BALLISTIC BAFFLES
IM	INTERCOM MICROPHONE/SPEAKER

1 PARTIAL ELECTRICAL SUB-BASEMENT – LIGHTING DEMOLITION PLAN
DE1.0 DE1.0 1:100

NOTES:

1. MAINTAIN THE INTEGRITY OF ALL EXISTING SYSTEMS REQUIRED TO REMAIN OPERATIONAL. IDENTIFY ALL CIRCUIT BREAKERS, WIRING, JUNCTION BOXES AND DEVICES PRIOR TO PROCEEDING WITH WORK. CONTACT OWNER/CONSULTANT IF UNSURE BEFORE SHUTDOWNS, DEMOLITION, OR RELOCATION OF ANY DEVICES.
2. ALL ITEMS SHOWN DASHED WITH AN 'E' ARE EXISTING AND ARE TO REMAIN OR BE RELOCATED AS REQUIRED. ITEMS SHOWN DASHED WITH A 'D' ARE TO BE DISCONNECTED AND REMOVED AND HAVE ALL ASSOCIATED WIRE AND CONDUIT REMOVED BACK TO SOURCE.
3. EXTEND, RE-ROUTE, RE-WIRE AND RE-CONNECT ALL EXISTING DEVICES TO BE RELOCATED.
4. WIRE AND CONDUIT SERVING DEVICES REQUIRED TO REMAIN IN USE SHALL BE RE-ROUTED AND DIVERTED AS REQUIRED TO MAINTAIN OPERATION. EXTEND, RE-ROUTE, RE-WIRE AND RE-CONNECT AS REQUIRED. CONFIRM EXISTING ON SITE.
5. NOT ALL DEVICES AND ELECTRICAL EQUIPMENT IS BEING SHOWN ON ELECTRICAL DRAWINGS. REMOVE ALL EXISTING ELECTRICAL DEVICES LOCATED ON INDICATED WALLS OR PORTIONS OF THE BUILDING BEING DEMOLISHED. MAINTAIN INTEGRITY OF ALL EXISTING ELECTRICAL SYSTEMS IN AREAS NOT INCLUDED IN THIS PROJECT AND IN PARTS OF THE BUILDING WITHIN RENOVATION THAT ARE NOT SUBJECTED TO ANY DEMOLITION WORK.
6. REFER TO SYMBOL SCHEDULE FOR ELECTRICAL SYMBOLS AND LETTER DESIGNATIONS.
7. NO SPLICING OF EXISTING AND NEW WIRING WILL BE ALLOWED IN THE BUILDING. EXISTING ELECTRICAL DEVICES REMAINING IN SAME LOCATIONS FED FROM RELOCATED PANELS HAVE TO BE REWIRED COMPLETELY TO NEW PANEL LOCATION. EXISTING PANELS AND OTHER DISTRIBUTION EQUIPMENT IN THE AREA OF DEMOLITION ARE TO BE DISCONNECTED AND REMOVED IF NECESSARY. THE EXISTING ASSOCIATED WIRING IS TO BE PULLED BACK TO THE SOURCE, REMOVED AND REPLACED WITH NEW WIRING.
8. EXISTING LUMINAIRES IN AREAS NOT DIRECTLY INCLUDED IN RENOVATION AREA TO REMAIN.
9. REPORT ANY DISCREPANCIES BETWEEN THE CONTRACT DOCUMENTS AND SITE OBSERVATIONS TO DEPARTMENTAL REPRESENTATIVE.
10. COORDINATE FINAL LOCATION OF LUMINAIRES WITH ALL OTHER TRADES..

PRELIMINARY
NOT FOR CONSTRUCTION

HDK HDK CONSULTING INCORPORATED
55-81 Garry St.
Winnipeg, Manitoba
Canada, R3C 4J9
T: 204.618.0386
F: 204.618.0388
www.hdkconsulting.com
info@hdkconsulting.com
Mechanical | Electrical | Communications | Security Engineering

APEGM
Certificate of Authorization
HDK Consulting Incorporated
No. 5539 Date: 04/30/2015



Revision	Description	Date
5		
4		
3		
2	ISSUED FOR CONSTRUCTION	FEB 23/15
1	ISSUED FOR 99% REVIEW	DEC 22/14
0	ISSUED FOR 50% REVIEW	OCT 20/14

Client: client

ROYAL CANADIAN MOUNTED POLICE D-DIVISION
1091 PORTAGE AVENUE
WINNIPEG, MANITOBA

Project: WINNIPEG, MANITOBA
1091 PORTAGE AVENUE
D-DIVISION HEADQUARTERS
FIRING RANGE UPGRADE

Designed by: HUGO CEA CANAS / PAUL LAPOINTE Conçu par

Drawn by: PAUL LAPOINTE Dessiné par

Approved by: HUGO CEA CANAS Approuvé par

PWOSC Project Manager: PAUL DUCHARME Administrateur de Projets TPSCC

Drawing title: PARTIAL ELECTRICAL SUB-BASEMENT LIGHTING DEMOLITION PLAN Titre du dessin

Project no./No. du projet	Drawing no./No. du dessin	Revision no.
	DE1.0 OF XX	0

