

2017 ROOF REPLACEMENT
SWIFT CURRENT, SASKATCHEWAN

.....
PMGM ARCHITECTURE LTD.
3434 REGINA AVENUE
REGINA, SK S4S 7J9

ADDENDUM NO. 2 – October 2, 2017

COMPRISED OF **ONE (1)** WRITTEN PAGES.

THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS AND MUST BE INSERTED IN ALL COPIES OF THE SPECIFICATIONS.

AMENDMENTS TO SPECIFICATIONS:

Section 07 52 00 – Modified Bituminous Membrane Roofing

Revise: Clause 3.08 – (Exposed) Conventional Membrane Roofing (CMR) Application

Item .2 - Tapered insulation application:

Revise to read: .1 Insulation to be adhered to the vapour barrier, and top layer of insulation to bottom layer of insulation, with manufacturer’s approved adhesive. Use bead spacing and size in conformance with CSA A123.21-14 test results.

.2 Install tapered insulation as second insulation layer, in accordance with shop drawings. Stagger joints between layers 150 mm minimum.