RCCRC

Questions and Answers

No./N° 3

Project Description / Description de projet						
			esearch Co	uncil U-72 Uplands		
Solicitation No./ N° de solicitation	Project No./N° d	le projet		W.O. No./N° d'ordre de travail		
17-22066						
Departmental Representative /	Date					
Représentant Ministériel	Date					
	Changed to October 10, 2017 at 2:00 PM					
Steve Cassidy						
Questions:		Answers:				
 Please extend the closing date to provide enough time to complete the bid after the amendment is published with the changes to comply with the SA specifications. 		 Closing date will be extended to October 10th, 2017New delivery date of November 20th, 2017. 				
across a number of items to contradict the SA. Althoug does allow for Non-SA pro- included with approval from Branch, we have noticed th SA specifications would pu of non-SA products well ow allowed 20%. Therefore, that the RFB be revised to additional specifications or exercise the option to cance and re-issue the request as	. In preparation of this bid, we have come across a number of items that contradict the SA. Although the SA does allow for Non-SA products to be included with approval from Acquisitions Branch, we have noticed that the non- SA specifications would put the amount of non-SA products well over the allowed 20%. Therefore, we would ask that the RFB be revised to remove these additional specifications or that you exercise the option to cancel the RFB and re-issue the request as an RFP with the specifications you require.		2. NRC is a custodial department that is not subject to the PSPC standard workplace 2.0 fit-up at this time. However having said that NRC had chosen to stay as close to the Government of Canada Standard as possible and have only made specific changes to the amenities within the standard to account for the unique work performed in most of our facilities. This being said all items in our fit- up may not fall within the SA's. We have chosen items off the SA that fit our specifications as closely as possiblewhen in question it is the specification document that should be referred to and referenced.			
 The following items from t specification do not comply Supply Arrangement or do correspond with the requir previously noted in the RFI 	/ with the not ements B documents.	3.		s listed please refer to the document as reference.		
1.8.2 - The panel heights must consist						

o s p p c a b	of a base panel with or without an add- onThis does not follow the SA specification in Annex A 3.4: base banels to be 28" to 38", worksurface privacy height to be 42" to 48" and consist of a base panel plus and add-on, and finally the seated privacy height to be 50" to 54" and consist of a base banel plus and add-on.	
h n 1 s t	Part 2, 2.2.1.3, as above, the panel neights in the SA at found in 6.1 "The overall panel height, including any panel nounted component must not exceed 37 m (54 in.). Panels must be stackable." The glass add-on exceeds he allowable height of the SA specification.	
а	Part 2, 2.2.2.2 requests glass. The SA Illows for glass, acrylic and plexiglass, Dease see Annex A 6.23.4.	
p S	Part 2, 2.2.6.1, the requirement of banels to stack up to 90" high is not an GA requirement, please see Annex A B.4.	
p n e P	Part 2, 2.2.8.1 The SA states "Fabric for banels, tack boards and seated cushions nust be manufactured from 100% ecycled material or from other environmentally appropriate materials." Please revise specification to adhere to hese requirements.	
P	Part $2,2,3,5,1,2$ the SA states that	

Part 2 2.3.5.1.2, the SA states that height adjustable tables with a sit/stand range must be capable of a height adjustment of 710mm to 1040mm (27 to 41 in.). The range of 27" to 45"

Part 2 2.3.7 Storage tower dimensions contradict the code

PSTxW2FCxxx2424Lxx listed. The code is for a 54"h max tower. Please advise what is required while keeping in mind that the SA does not allow for the tower to exceed the height of the seated privacy height panel when located within a workstation.

Part 2 2.3.8 The SA does not allow for a Tool Bar, but does allow for an Accessory Element, please see Annex A 6.19 "Panel-mounted accessories must be

integrated into the panel frame or

attached to the panels separately. Panel-mounted accessory widths must correspond with panel widths". Part 2 2.3.12.3 The SA allows for duplex and triples outlet, not simplex. Please see Annex A 6.14.4 "Each workstation must be provided with three (3) duplex power outlets six (6) receptacles and one (1)voice / data outlet."	
4. 2.1.2 - You have listed a limited number of acceptable manufacturers but it is our understanding that under the Supply Arrangement any SA holder would be an acceptable bidder for the Category that they hold under the SA. Please confirm that all bidders who hold Supply Arrangements for Category 1, 2, 3 and 5 are acceptable.	4. All manufacturers meeting the specifications outlined within our reference documents are welcome to bid.

Upon request, the text above can be provided in French.



National Research Council Canada Conseil national de recherches Canada

