



RETURN BIDS TO:
 RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
 Mailroom
 30 Victoria Street
 Gatineau, Quebec, J8X 0B3**

Amendment #2

INVITATION TO TENDER
 APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Vendor/Firm Name and Address

Raison sociale et adresse du
 fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
 Mailroom
 30 Victoria Street
 Gatineau, Quebec, J8X 0B3**

Title-Sujet Baron Lab HVAC		Date 06 October , 2017	
Solicitation No. - No. de l'invitation 5P047-17-5170		Client Ref. No. - No. de réf du client.	
GETS Reference No. - No de reference de SEAG			
Solicitation Closes L'invitation prend fin - at - à 02:00 PM on - le 2017-10-13		Time Zone Fuseau horaire - Eastern Daylight Time (EDT)	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>			
Address Inquiries to: - Adresser toute demande de renseignements à : Patrick Sullivan at Patrick.Sullivan@pc.gc.ca			
Telephone No. - No de téléphone (819) 420-9557		Fax No. - No de FAX:	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein			
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur			
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur			
Signature		Date	



AMENDMENT #2

THE PURPOSE OF THIS AMENDMENT IS TO POST QUESTIONS AND ANSWERS

Q1: Can the make up air unit sit on the attic floor or does it need a crib etc?

A1: It can sit on the floor, but it might be good to put a rubber pad or something under it.

Q2: What is the routing of ef1 and ef2 to the exhaust air plenum? (not shown)

A2: Route to exhaust air plenum shown on drawing M102, Detail 2/M102.

Q3: M103 - drawing 9 - What louver is required? What is the height required?

A3: It is called out on Drawing M102, Detail 1/M102 (36" x 12")

ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED