Can-Tec Project No: 16-045-01-30

Part 1 ADDENDUM NO. 3

1.1 General

- .1 This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2 In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

Part 2 Questions

In 09 65 16 2.1.8, the spec asks for a $\frac{1}{2}$ " underlayment plywood – to my knowledge such a format is no longer manufactured. It once was, but the costs of commodities has driven it out of the market. Most commonly are products that sit in the $\frac{1}{4}$ " area (3/16 and 5/16 most commonly). Is the $\frac{1}{2}$ " specified to match an existing height, or is this an old spec that's being re-used?

1/4" and 5/16" underlayment materials are acceptable – The product chosen must be compatible with the chosen flooring to ensure that the flooring warranty will remain valid. Supply a cut sheet with the shop drawings.

END OF SECTION