



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Multi-Purpose Building Construction	
Solicitation No. - N° de l'invitation K4A22-180297/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client K4A22-180297	Date 2017-10-10
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-8184	
File No. - N° de dossier PWY-7-40183 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-10-16	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: EC - Pacific Wildlife Research Centre - Westham Island - Delta, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
K4A22-180297/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

Les documents en français seront disponibles sur demande.

The Solicitation Amendment 002 is raised to issue Addendum 001

Please see Addendum 001 herein

All other terms and conditions remain unchanged.

GENERAL

The following changes in the Tender Documents are effective IMMEDIATELY. This addendum will form part of the Contract Documents

DRAWINGS

None

SPECIFICATIONS

None

CLARIFICATIONS

1. For the area of cladding replacement noted on the drawings for the observation tower, allow for 20% replacement of the sheathing under the cladding.
2. Tower exterior siding profile to match existing; a 2 piece profile.
3. Construction Completion: Construction is to be completed 32 weeks after contract award.
4. Contractors have use of an onsite portable toilet.

QUESTIONS

Question 1 (Received 2017-10-05)

Q: How is the picnic shelter connected?

A: Picnic Shelter is bolted directly to existing concrete slab, no special finishes underneath.

Question 2 (Received 2017-10-05)

Q: Is the sewage pump chamber being removed as part of contract?

A: Yes, Sewage pump chamber is to be removed and new provided as per drawing and specifications.

Question 3 (Received 2017-10-05)

Q: Can we dump stripped sod & top soil from excavation on site?

A: Yes, a location will be provided on site for the stripped sod and excavated top soil

Question 4 (Received 2017-10-06)

Q: At the site walkthrough yesterday – it was observed that the existing Asphalt/Gravel Roadway/Pathway is somewhat aged and deteriorated. Throughout the construction process, there is a good chance that the deterioration will be accelerated.

Could the consultants possibly address this by incorporating a requirement with associated specification for new Asphalt/Gravel - Roadways/Pathways?

A: Contractor to include as part of the bid price, replacement of asphalt walk and driveway damaged during construction. Refer to specifications for asphalt paving requirements.

Question 5 (Received 2017-10-05)

Q: What is to be done with the brush on west side of the new building?

A: Removed and disposed of offsite.

Question 6 (Received 2017-10-05)

Q: Are deliveries a problem at site?

A: No, deliveries are not a problem at site. The bridge to Westham Island has a loading restriction, verify that deliveries are below this weight. This is especially relevant for concrete deliveries.

Question 7 (Received 2017-10-05)

Q: Are alternatives to the specified picnic shelter okay and does the structure require engineered shop drawings?

A: Yes, alternates for approval are acceptable. Shop drawings to be signed and sealed by an engineer registered in the Province of British Columbia.

Question 8 (Received 2017-10-06)

Q: At the site meeting it was suggested that the GC's could use the owners power during construction – as there was room on the panel in the Existing Generator Shed. Could you please confirm?

A: Adequate temporary power is available at the generator shed.

Question 9 (Received 2017-10-06)

Q: At the site walkthrough – it was stated that the shrubbery would need to be removed – however this is not shown on the tender documents. Could you please confirm that it does in actual fact require removal? Also, are there any of the shrubs/trees/plants etc. that are to be retained or relocated?

A: Include removal and disposal on site of the shrubbery east of the end the asphalt path and just west of the multi-use building site. No shrubs or trees within this area are to be retained or relocated.

Question 10: (Received 2017-10-06)

Q: Could you please have your consultants define the specification requirements (for the picnic shelter roof). Also - do you know the Wind Load/Snow Load/Seismic Design?

A: The roof to be Standing Seam (Poligon SS). Design load requirements per the structural design notes on S111.

Question 11: (Received 2017-10-06)

Q: Spec 03 35 00 Page 4 advises an extent of Epoxy Flooring required. Can you provide Epoxy Flooring Specification please?

A: Please refer to 09 91 99 Painting for finish specifications.

END OF ADDENDUM 1