



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Building Envelope Rehabilitation	
Solicitation No. - N° de l'invitation F1700-174255/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client F1700-174255	Date 2017-10-13
GETS Reference No. - N° de référence de SEAG PW-\$PWY-022-8185	
File No. - N° de dossier PWY-7-40209 (022)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-10-23	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Arthur (PWY), Carolyn	Buyer Id - Id de l'acheteur pwy022
Telephone No. - N° de téléphone (604) 364-2752 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Kitsilano Coast Guard Station - Vancouver, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 004

Amendment 004 is raised to:

- 1) Incorporate Addendum #2 dated October 13, 2017
- 2) Provide response to bidder questions

-
- 1) Please see attached addendum #2
 - 2) Responses to bidder questions

Q1: What is the existing roof composition – no notes in drawings or specifications?

A1: Based on the RDH Report & the as-built drawings from 1993:

The main roof is composed of:

- SBS roofing membrane system
- Fiberboard
- Rigid Insulation
- Vapour Barrier
- Gypsum Sheathing Board
- Steel Decking & Structure

The only reference to the thickness of the insulation is on sheet A11 of the as-builts, which refers to 165mm max. thickness. I assume that the nominal insulation thickness (minus tapering) is 150mm.”

Q2: Should GC determine; Is after hours and/or weekend work permitted?

A2: Please refer to Spec. Work Restrictions 1.3

Q3: Are the existing metal framed Interior partitions to remain as is and not to be included in this scope of work.?

A4: This was addressed in the addendum 1. Please refer to Addendum #1 dated October 12, 2017.

All other terms and conditions to remain unchanged.

ADDENDUM 02

This Addendum is in addition to, and forms a part of the Contract. The cost, if any, of this revision(s) shall be included in the Contract price. All bidders shall acknowledge receipt and acceptance of this addendum by indicating Addendum number, date, and description, on the Tender Form provided. The revision(s) is as follows:

REFERENCE SPECIFICATIONS AS FOLLOWS:

1. Section 07 42 43 – Composite Wall Panel System

Delete: 2.1.3 Thickness: 7-8mm

Add: 2.1.3 Thickness: 12mm

END OF ADDENDUM