


- LEGEND:**
- ◇ TERMINAL UNIT
 - ◇ SEE DEMOLITION NOTES FOR DESCRIPTION.
 - ① NEW MECHANICAL EQUIPMENT. SEE MOTOR STARTER AND CONTROL LIST FOR INFORMATION.
 - VFD VARIABLE FREQUENCY DRIVE SUPPLIED AND INSTALLED BY MECHANICAL CONTRACTOR, WIRED BY ELECTRICAL CONTRACTOR. USE VFD RATED CABLE FROM VFD TO MOTOR.
 - D[S] EXISTING FIRE ALARM DUCT MOUNTED SMOKE DETECTOR TO BE REMOVED FROM EXISTING DUCTWORK AND RE-INSTALLED ON NEW DUCTWORK. PROVIDE FIRE ALARM VERIFICATION REPORT ON RELOCATED DEVICE.
 - [R] EXISTING FIRE ALARM FAN SHUTDOWN RELAY TO BE RE-USED FOR FAN SHUTDOWN ON NEW SUPPLY AND RETURN FANS. PROVIDE FIRE ALARM VERIFICATION REPORT ON RELOCATED RELAYS.
 - NF □ NON-FUSED DISCONNECT SWITCH



DUMAC ENERGY LTD.
CONSULTING ENGINEERS
752 BEDFORD HIGHWAY
HALIFAX, N.S.
Tel: (902) 462-1500
Fax: (902) 462-1777
Email: info@dumac.ca



1	FOR TENDER	17.03.31
revisions		date
project	BEDFORD INSTITUTE OF OCEANOGRAPHY HOLLAND WEST VENTILATION UPGRADE DARTMOUTH NS	
drawing	ELECTRICAL FLOOR PLANS AND LEGEND	
designed	STAFF	conçu
drawn	STAFF	dessiné
approved		approuvé
date	17.03.31	
Tender		Soumission
PWGSC Project Manager	Administrateur de projets TPSCC	
project number	R.082149.001	no. du projet
drawing no.	E-2	no. du dessin