RETAIN ALL DIFFUSERS AND GRILLES FOR REINSTALLATION. REFER TO M102 FOR NEW LOCATIONS OF ALL GRILLES AND DIFFUSERS.

ALL DIFFUSERS AND GRILLES WITHIN THE PROJECT CONSTRUCTION AREA SHALL BE REMOVED AND DUCT CAPPED AND SEALED DURING CONSTRUCTION. ALL GRILLE/DIFFUSERS SHOWN AS EXISTING TO REMAIN SHALL BE REINSTALLED AFTER CONSTRUCTION AND REBALANCED.

3-AF T'STAT

HVAC DEMOLITION PLAN

1 / H1

SCALE/ÉCHELLE : 1:50

0m 1m 2m 3m 4m 5m

PWGSC A1 (2004)

Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

ARCHITECTURE + SUSTAINABLE DESIGN
SableARC STUDIOS
49 Water Street, Charlottetown PE C1A 1A3 - t. 902.816.0216
rhaggis@sablearc.com / www.sablearc.com

ORANGE DOOR ENGINEERING
49 Water Street, Charlottetown PE C1A 1A3 - t. 902.388.7685
joe@orangedoor.org / www.orangedoor.org

PROFESSIONAL ENGINEER
J.G. Bystryk
1535
2017/10/03
PROVINCE OF PRINCE EDWARD ISLAND

1.	ISSUED FOR 33% PROGRESS SET	17.08.02
2.	ISSUED FOR 66% PROGRESS SET	17.08.21
3.	ISSUED FOR 99% PROGRESS SET	17.09.13
4.	ISSUED FOR TENDER	17.10.03
revisions		date

project / projet

CID OFFICE RENOVATION – JOSEPH A. GHIZ BUILDING

SUMMERSIDE/PE

drawing / dessin

HVAC LAYOUT DEMOLITION

designed	Joe Bystryk	conçu
date	2017.08.02	
drawn	Joe Bystryk	dessiné
date	2017.08.02	
approved	Joe Bystryk	approuvé
date	2017.08.02	
Tender	2017.08.02	Soumission
PWGSC Project Manager		Administrateur de projets TPSGC
project number	R.090981.001	no. du projet
drawing no.	H2 of 3	nº du dessin

E-DRM/GDD-E: 552508