



# TENDER AMENDMENT

**RETURN BIDS TO:**

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3  
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

**Issuing Office:**

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3

# MODIFICATION D'APPEL D'OFFRES

**RETOURNER LES SOUMISSIONS À :**

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300,  
Calgary, AB T2P 3M3  
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Bureau de distribution :**

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300  
Calgary (AB) T2P 3M3

<b>Title:</b> Protection Mountain Campground Electrical Supply – Banff National Park		
<b>Solicitation No.: / N° de l'invitation :</b> 5P420-17-5342/A	<b>Amendment No.: / N° de modification de l'invitation :</b> 002	<b>Date:</b> October 16, 2017  <b>Date :</b> 16 octobre 2017
<b>GETS Reference No.: / N° de référence de SEAG :</b> PW-17-00797650		
<b>Solicitation Closes: / L'invitation prend fin :</b>		
<b>At:</b> 02:00 PM	<b>On:</b> October 19, 2017	<b>Time Zone:</b> Mountain Daylight Time (MDT)
<b>À :</b> 14h00	<b>Le :</b> 19 octobre 2017	<b>Fuseau horaire :</b> Heure avancée des Rocheuses (HAR)
<b>Address Inquiries to: / Adresser toute demande de renseignements à :</b> Danny Ahn		
<b>Telephone No.: / N° de téléphone :</b> (403) 292-5451	<b>Fax No.: / N° de télécopieur :</b> 1-866-246-6893	<b>Email Address: / Courriel :</b> Danny.ahn@pc.gc.ca
<b>TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)</b>		
<b>Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur</b>		
<b>Address - Adresse</b>		
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>		
<b>Title - Titre</b>		
<b>Signature</b>		<b>Date</b>

## **Amendment 02**

This amendment is being raised to distribute Questions & Answers from the mandatory site visit. All such revisions will become part of the Work and the effects shall be included in the Tender Price. All work shall be performed in accordance with the Contract Documents.

### **A) Site Visit Attendees**

Please see next page.

### **B) Questions and Answers**

**Q1.** Can existing power poles be re-used?

**A1.** Power poles to be re-used are shown on the drawings.

**Q2.** Do poles that are flagged for removal need to be removed and disposed off site?

**A2.** Yes, power poles that are to be removed as shown on the drawings are to be removed and disposed off site.

**Q3.** What is the requirement for excess material from the excavation?

**A3.** Excess material from excavation is to be removed and disposed off site as per Spec 31 20 10.

**Q4.** Are washrooms operational during construction?

**A4.** No. Water is not available. Water has been shut off to all buildings within the campground.

**Q5.** Do anchor rods need to be removed?

**A5.** Please Note: The answer provided during the pre-tender meeting was that any anchor rods within the planting beds needed to be removed 3 feet below surface, and any others needed to be removed completely. After further discussions it has been decided that all anchors can be removed 3 feet from surface, full removal is not required.

**Q6.** Are Tree removals allowed?

**A6.** Yes, follow requirements as outlined in the Basic Impact Analysis. Trees that are removed are to be disposed of off site.

**Q7.** Does the new underground line follow the existing alignment?

**A7.** Yes

**Q8.** Can Parks Canada pits be used for waste material?

**A8.** No, all waste material must be removed and disposed off site.

**All other terms and conditions remain the same.**

