



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Existing Utility Rehabilitation	
<b>Solicitation No. - N° de l'invitation</b> EZ899-181109/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2017-10-19
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-031-8186	
<b>File No. - N° de dossier</b> PWY-7-40206 (031)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-10-31</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Leung, Janie	<b>Buyer Id - Id de l'acheteur</b> pwy031
<b>Telephone No. - N° de téléphone</b> (778) 919-3273 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Parks Canada - Fort Langley National Historic Site - Fort Langley, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-181109/A

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur  
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier  
PWY-7-40206

CCC No./N° CCC - FMS No./N° VME

---

**Les documents français seront disponibles sur demande.**

This Amendment #001 is raised to extend the solicitation closing date, to address questions, and to issue Addendum #1.

**Extension of Solicitation Closing Date**

\*\*\*\*\*

Extension of Time for Tenderers

**Existing Utility Rehabilitation  
Fort Langley National Historic Site, Fort Langley, BC  
Solicitation No: EZ899-181109/A**

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. P.D.S.T. on 24 October 2017 is hereby extended to **2:00 p.m. P.D.S.T. on 31 October 2017.**

\*\*\*\*\*

**Questions and Answers**

**Q1.** Would we be able to coordinate access to the site?

**A1.** Please contact the Contracting Authority, Janie Leung, and she will provide you with the contact person to set this up.

See attached Addendum #1.

**All other terms and conditions remain unchanged.**

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

**1. Reference Technical Specification, Section 01 11 55,**

Add clause 2.2.13 “Contractor shall coordinate and pay all costs to the Township of Langley for the installation of the offsite sanitary and storm connections as indicated on the drawings. The Contractor shall include an allowance of \$25,000 for the sanitary sewer connection by the Township of Langley and \$40,000 for the storm connection installation by the Township of Langley. The Contractor shall connect onsite the storm and sanitary services at the property line to the offsite services installed by the Township. Any difference between the final invoices from the Township of Langley and above noted allowances will be addressed via Change Order. Payments to the Township of Langley by the Contractor are to be made at the Civic Facility front counter at 20338 65 Avenue, Langley BC.”

**2. Reference Issued for Tender Drawings, Sheet 6 of 11**

Replace Sheet 6, “Issued for Tender” dated 2017/08/15 with attached Sheet 6 “Issued for Addendum #1” dated 2017/10/18.

**Tender Questions**

During the tender period Public Services and Procurement Canada has received various questions from Contractors. The following section lists the questions and the responses. The cost implication of the responses provided are to be included in the tender price.

**1. Is imported trench backfill required on all trenches?**

Imported trench backfill is not specifically required on all trenches provided adequate compaction can be achieved. Imported backfill is required under any pavement surface.

**2. Is the Township of Langley providing costs for the following to be incorporated in the tender price?**

- a. Overbuild 1050mm M/H (S1) at Mavis Avenue (sheet 3 of 11)**
- b. 450mm Storm Sewer at River Rd (sheet 8 of 11)**

An allowance is provided as per item 1 of this addendum. The 1050mm diameter over build manhole and sanitary sewer service line to the property line is included in the Township’s offsite work. The sampling manhole is separate from the Township’s work and shall be supplied and installed by the Contractor. The 450mm storm crossing River Road is included Township’s offsite works. Connection of the existing storm manhole onsite is to be completed by the Contractor.

- 3. There are bold water lines indicated on sheet 6 without sufficient details for pricing. Please provide additional detail?**

Sheet 6 has been revised and attached to address the missing detail. A note has also been added to indicate the required temporary relocation of the gold panning exhibit. The Contractor will be responsible to reinstate the gold panning exhibit.

- 4. Is drawing M-11 included?**

Drawing M11 is part of the tender set of drawings and the Contractor is responsible for all work indicated on the drawing which includes abandonment of the existing pump station and installation of a new connection for the existing pump station inlet to the new gravity service to the building. The Contractor is required to confirm all internal elevations in advance of completing the work.

- 3. Who is responsible to obtain and pay for Plumbing Permit Fees?**

As the project is located on Federal land, plumbing permit fees are not applicable and no allowance is required.

- 4. How it will be dealt with if the archeologist stops us from working? Will we be put onto standby until he gives us the green light again?**

Standby time for archaeological work is at the risk Public Services and Procurement Canada and will be paid for by change order if necessary.

- 1. Drawing # 10 shows a detail of the required meter chamber and has a component labelled as “# 2” : 200 dia Badger W5000 magmeter. This description is followed by the words ‘F x F steel spool provided’? What is the intention of these words? Are we providing only a F x F steel spool instead of the meter and the meter will be by others at no cost to the contractor ?**

The Contractor shall include for the supply and installation of the indicated water meter and a flange by flange spool piece of equal length to the meter provided loose.

----End of Addendum----

