

**Electrical System Upgrade****Larry's River****Guysborough County, NS****Project No. R.094341.001**

Miscellaneous Items

Page 1

PART 1 - GENERAL1.1 Description  
of Work

- .1 This section specifies requirements for the following items:
  - .1 Ladders

1.2 Reference  
Standards

- .1 ASTM A307-14 (or latest edition), Specification for Carbon Steel Bolts and Studs, 60,000 psi Tensile.
- .2 ASTM A123/A123M-13 (or latest edition), Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.CAN/CSA
- .3 CAN/CSA G40.21-M13 (or latest edition), Structural Quality Steels.
- .4 CAN/CSA-S16-14 (or latest edition), Design of Steel Structures.
- .5 CAN/CSA W59-13 (or latest edition), Welded Steel Construction (Metal Arc Welding).
- .6 CAN/CGSB-1.181-1999 (or latest edition), Ready-Mixed Organic Zinc-Rich Coating.

1.3 Related Work

- .1 Refer to other Specification Sections for related information.
- .2 Refer to **Section 01 33 00** for Shop Drawing/Submissions requirements.

1.4 Submissions

- .1 Shop Drawings:
  - .1 Clearly indicate the following items:
    - .1 General arrangements, dimensions, clearance locations and directions of assemblies as installed on structures.
    - .2 Locations, sizes and installation tolerances of anchor bolts, eye bolts and embedded parts.
    - .3 Types of materials used, finishes and core thickness.
    - .4 All other pertinent details and accessories.
- .2 Product Data/Samples:

**Electrical System Upgrade**

Larry's River

Guysborough County, NS

Project No. R.094341.001

## Miscellaneous Items

Page 2

- 
- .1 Provide product data and manufacturers brochures for the mooring cleats.
  - .3 Test Results:
    - .1 Provide test results for the galvanized items.
  - .4 Submissions
    - .1 Provide submissions in accordance with **Section 01 33 00.**
- 1.5 Measurement for Payment
- .1 Ladders, including timber, rungs, and fasteners will be measured in accordance with **Section 01 29 00.**

PART 2 - PRODUCTS

- 2.1 Materials
- .1 Timber: Any timber supplied by Contractor must conform to **Section 06 05 73** Dimension Timber.
  - .2 Hardware and miscellaneous steel items must meet the following specifications:
    - .1 Machine bolts, lag bolts, drift bolts, anchor bolts, nuts, washers to ASTM A307.
    - .2 Steel plates, ladder rungs, holdfasts and miscellaneous steel: to CSA G40.21, Grade 300W.
    - .3 Mooring cleats: cast iron to ASTM A48, Class 25, with approximate weight of 41kg (90 lb.) each.
    - .4 Do not use items manufactured or fabricated from scrap steel of unknown chemical composition or physical properties.
    - .5 Hot dip galvanize bolts, anchor bolts, nuts, washers, pipe sleeves, steel plates, rungs, holdfasts U-bolts and any other miscellaneous steel to CSA A123 with minimum zinc coating of 600 g/m<sup>2</sup>.
    - .6 The material requirements for installation of light poles are given in the electrical sections/drawings.

**Electrical System Upgrade****Larry's River****Guysborough County, NS****Project No. R.094341.001**

Miscellaneous Items

Page 3

PART 3 - EXECUTION3.1 Ladders

- .1 Assemble ladder units and install completed units in locations shown on plan or as indicated by *Departmental Representative*.
- .2 Countersink bolts on exterior face of ladder.
- .3 Apply preservative to areas of unprotected wood exposed during course of work in accordance with **Section 06 05 73**.

3.9 Installation  
General

- .1 Boreholes for drift bolts to be 1.5mm smaller in diameter than bolt and for full length of bolt. Boreholes for machine bolts to be same diameter as bolts. Boreholes for lag bolts to be same diameter as shank for unthreaded portion and 0.70 times the shank diameter for the threaded portion. Threaded portion of lag bolts will be installed using a wrench, not by driving.
- .2 **Contain all debris and leachates (films on water surface) within the area of the work by using containment facilities such as floating**