



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
The Cambridge Building  
3 Queen Street/ 3, rue Queen  
Charlottetown, PEI C1A 4A2  
Bid Fax: (902) 566-7514

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Commercial Acquisitions (PEI)  
The Cambridge Building  
3 Queen Street/3 rue, Queen  
Charlottetown, PEI C1A 4A2

<b>Title - Sujet</b> Office Renovation-JAG Bldg, PEI	
<b>Solicitation No. - N° de l'invitation</b> ED001-181544/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> ED001-181544	<b>Date</b> 2017-10-26
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWC-023-4204	
<b>File No. - N° de dossier</b> PEI-7-40095 (023)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-10-31</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ellis-Herring, Alison	<b>Buyer Id - Id de l'acheteur</b> pwc023
<b>Telephone No. - N° de téléphone</b> (506) 636-3908 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
ED001-181544/A

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur  
PWC023

Client Ref. No. - N° de réf. du client  
R.090981.001

File No. - N° du dossier  
PEI-7-40095

CCC No./N° CCC - FMS No./N° VME

This Solicitation Amendment No. one (1) is raised to include the following addendum no. 1.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 1.

## **1. DRAWINGS**

Ref: Revised Drawing H2: Issued for Addendum #1, 2017.10.26 (attached separately)

- .1 Existing radiators in the space shall be removed. Add notes to the drawing: "Remove existing convector in all respects. Break wall to cut pipe inside wall. Restore wall to match adjacent conditions. Cap piping above ceiling." Locations are shown on the drawings.
- .2 Existing compressed air line shall be removed. Add note to the drawing: "Remove existing air line to above the ceiling and cap." Location is shown on the drawing.
- .3 Add a general note to the drawing: "Contractor to coordinate shut-downs with the Departmental Representative as required in order to cut and cap services."