

Questions & Requests for Equals ET025-180083/A RCMP "D" Division Range Upgrade to Oct 23, 2017

Item	Date	Question	Answer
3	24/10/2017	<p>1. Drawing A1.0, A1.1, A1.2, Construction General Notes #E indicted “Refer to room finish schedule for extent of new finishes.”. There isn’t any room finish schedule provided in the tender documents. Please provide room finish schedule so we can price accordingly.</p> <p>2. The drawings and specification contradict each other for resilient flooring. Section 09 65 10 RESILIENT FLOORING, Page 1 of 3 says Rubber Floor Tile but the Drawing RCMP Winnipeg Issued for Construction Part 4 in the Drawing Keynotes BOX 17 and BOX 18 it says its Sheet Rubber Flooring. Which product we should use for the flooring, Rubber Tile or Rubber Sheet Goods? Please advise so we can price accordingly.</p>	<p>1) Refer to interior elevations on Drawing A1.1 for extent of finishes. Refer to Specifications for finish requirements.</p> <p>2) Provide pricing for Rubber Tile as per spec.</p>