



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
The Cambridge Building
3 Queen Street/ 3, rue Queen
Charlottetown, PEI C1A 4A2
Bid Fax: (902) 566-7514

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Commercial Acquisitions (PEI)
The Cambridge Building
3 Queen Street/3 rue, Queen
Charlottetown, PEI C1A 4A2

Title - Sujet Office Renovation-JAG Bldg, PEI	
Solicitation No. - N° de l'invitation ED001-181544/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client ED001-181544	Date 2017-10-26
GETS Reference No. - N° de référence de SEAG PW-SPWC-023-4204	
File No. - N° de dossier PEI-7-40095 (023)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-10-31	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ellis-Herring, Alison	Buyer Id - Id de l'acheteur pwc023
Telephone No. - N° de téléphone (506) 636-3908 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
ED001-181544/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
PWC023

Client Ref. No. - N° de réf. du client
R.090981.001

File No. - N° du dossier
PEI-7-40095

CCC No./N° CCC - FMS No./N° VME

Cette modification à l'invitation numéro deux (2) est soumise pour inclure l'addenda numéro 2 suivant.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant.
L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 2.

1. DEVIS

1. SPECIFICATIONS

.1 Ref: Section 08 11 00 Metal Doors and Frames:

.1 Ref: Paragraph 2.1 Materials:

.1 Add:

.1 ".5 Provide acoustic metal doors to meet STC rating of adjacent walls."

.2 Ref: Paragraph 2.5 Accessories:

.1 Delete:

.1 ".3 Adjustable Jamb sound seal to maintain STC rating of adjacent wall type."

.2 ".4 Automatic door bottom sound seal. Mortise application to maintain STC rating of adjacent wall type."

.3 Ref: Paragraph 2.6 Frames Fabrication General:

.1 Add:

.1 ".10 Provide acoustic metal frames to meet STC rating of adjacent walls"

.2 Ref: Section 08 71 00 Hardware:

.1 Ref: Paragraph 3.6 Schedule:

.1 Delete requirement for Pick plates and Latch blockers from doors 100.1, 100.2, 101.1.

2. QUESTION ET RÉPONSE

Q1. You want the door openings to meet the STC 52 rating. Are the exiting doors sound rated. I cannot find from my suppliers sound seals and auto door bottoms that will meet the STC 52. The only way is to get sound rated doors and frames that already come with the seals. Can you please specify what seals you want that meet the STC 52. Are the new doors and frames for openings 101.1 & 102.1 to

Solicitation No. - N° de l'invitation
ED001-181544/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
PWC023

Client Ref. No. - N° de réf. du client
R.090981.001

File No. - N° du dossier
PEI-7-40095

CCC No./N° CCC - FMS No./N° VME

be sound rated. Also you have a latch blocker specified for the rated door. Why do you a As far as I have told you can not have this as a rated door has to self close and self latch. Why do you have a pick plate for doors that swing in as you can not get at the latch due to the stop strip.

R1. Refer to Item 1 of this Solicitation Amendment Two (2).