



AMENDMENT #3 MODIFICATION #3

RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
National Contracting Services
Bid Receiving Unit
111, Water Street East
Cornwall ON K6H 6S3

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Issuing Office - Bureau de distribution

Parks Canada Agency
111, Water Street East
Cornwall ON K6H 6S3

Title-Sujet Replacement of Warves at Black Rapids Lock station		
Solicitation No. - No. de l'invitation 5P300-17-5408/A		Date: October 27, 2017
GETS Reference No. - No de reference de SEAG		Client Ref. No. - No. de réf du client. 1371
Solicitation Closes:		
at - á 02:00 PM	on - le November 01, 2017	Time Zone - Fuseau horaire EDT - HAE
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: X Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Patrick Alguire - patrick.alguire@pc.gc.ca		
Telephone No. - No de téléphone (613) 938-5955		Fax No. - No de FAX: (877) 558-2349
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein - Voir dans la présente		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm	
Titale - Titre	
Telephone No. - N° de téléphone:	
Facsimile No. - N° de télécopieur:	
Email - Courriel:	
Signature	Date

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

1. Extension to the solicitation closing date

The solicitation closing has been extended to Wednesday, November 1, 2017 at 2:00 p.m. EDT. If you have already submitted your bid, you are invited to send us your revisions, where necessary, by fax to 1-877-558-2349. Please indicate the number of the invitation to tender on all correspondence.

2. Revision and clarification to questions and answers from Amendment #2

Question 17: Section 06 08 99-Timber Retaining Wall .1 – “All timbers to be pre-cut and pre-bored prior to preservative treatment.” Is it the intent of the owner to have the contractor build the retaining wall on site to accommodate the existing/final grade drill and bolt/pin it together, then take the wall apart and send for the preservative treatment?

Answer 17: Original response: *Commercially available treated wood to be used. Cut and bores to be treated with hand applied preservative.*

Additional Clarification: No, as we indicated in amendment No 2 the retaining wall can be built with commercially available treated wood. So delete the sentence “All timbers to be pre-cut and pre-bored prior to preservative treatment.” Add the following sentence “Field cuts, bores and drilled holes shall be treated with hand applied wood preservative.”

Question 19: Section 31 53 13.01 – Crib Construction. “Precut and pre-bore timber prior to preservative treatment.” Is it the intent of the owner to have the contractor build the timber cribs on site to accommodate the existing/final grade figure out the required angles/orientation and bolt/pin the cribs together, then take the cribs apart and send for the preservative treatment?

Answer 19: Original response: The timer drills, cuts and bores to be treated on site with matching wood preservative.

Additional Clarification: No, it is not our intent to have the Cribs assembled prior to pressure treatment. All Crib work timber to be treated as per specification. All holes, bores and cuts shall be made in the factory prior to preservative treatment. The Shop Drawings submitted by contractor shall indicate the exact location of all holes, bores and cuts to assure the correct assembly of the cribs on-site.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.