



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Existing Utility Rehabilitation	
Solicitation No. - N° de l'invitation EZ899-181161/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client	Date 2017-11-02
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-8183	
File No. - N° de dossier PWY-7-40222 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-11-09	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada (PCA) - Fort Rodd Hill National Historic Site - Colwood, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation. - N° de l'off. à comm.
EZ899-181161/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
pwy036

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-7-40222

CCC No./N° CCC - FMS No/ N° VME

This Amendment #004 is raised to issue the following changes:

Extension of Solicitation Closing Date

Extension of Time for Tenderers

Existing Utility Rehabilitation – Parks Canada
Fort Rodd Hill National Historic Site, Victoria, BC
Solicitation No: EZ899-181161/A

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. P.S.T. on 6 November 2017 is hereby extended to 2:00 p.m. P.S.T. on 09 November 2017.

This Amendment #004 is also raised to issue Addendum #04.

Please see Addendum #04 herein.

The addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

Tender Questions

During the tender period Public Services and Procurement Canada has received various questions from Contractors. The following section lists the questions and the responses. The cost implication of the responses provided are to be included in the tender price.

1. Please confirm that the temporary water main is to be 150mm diameter HDPE DR11?

Yes. See addendum 3

2. For temporary water confirm if pressure and health tests are required prior to connection?

Yes, testing and commissioning of the temporary water service is required.

3. Please confirm if the price is to be based on the schedule of quantities included in the Specifications?

No. The lump sum price shall be based on the drawings. See addendum 3.

4. Please confirm fire hydrant requirements?

Hydrants to comply with City of Colwood standards as the local authority having jurisdiction.
Hydrants shall include one valve.

----End of Addendum----