

To: Jill Sparling  
McRobie Architects + Interior Designers

Date: November 1st, 2017

Reference: CFIA Ottawa Laboratory – A Wing Washrooms Refurbishment

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification.

Clarifications

1. Lighting schedule referred to on electrical drawings is attached below.

<u>LIGHTING FIXTURE SCHEDULE</u>				
<u>LABEL</u>	<u>MANU.</u>	<u>MODEL NUMBER</u>	<u>ARR. WATTS</u>	<u>ARR LUM MUMENS</u>
A	SENSO LATONA 1	679-581-613-60-08-07-DIM	10	602
A1	SENSO LATONA 1	679-581-613-60-08-10-DIM	13	860
B	SENSO LATONA 1	515-581-613-60-08-10-DIM	13	860
L1-2	AXIS LIGHTING	SCR-300-80-35-0.5M-K-W-120-D1-TB9	11.7	1200
L1-4	AXIS LIGHTING	SCR-300-80-35-0.5M-K-W-120-D1-TB9	11.7	1200
W	AXIS LIGHTING	SCR-PRWLED-B3-MF-500-80-35-5-6FT -W-120V-D-1	32.7	3600

END OF ADDENDUM