



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Existing Utility Rehabilitation	
Solicitation No. - N° de l'invitation EZ899-181161/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client	Date 2017-11-07
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-8183	
File No. - N° de dossier PWY-7-40222 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-11-15	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada (PCA) - Fort Rodd Hill National Historic Site - Colwood, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation. - N° de l'off. à comm.
EZ899-181161/A

Amd. No. - N° de la modif.
005

Buyer ID - Id de l'acheteur
pwy036

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-7-40222

CCC No./N° CCC - FMS No/ N° VME

This Amendment #005 is raised to issue the following changes:

Extension of Solicitation Closing Date

Extension of Time for Tenderers

Existing Utility Rehabilitation – Parks Canada
Fort Rodd Hill National Historic Site, Victoria, BC
Solicitation No: EZ899-181161/A

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. P.S.T. on 09 November 2017 is hereby extended to 2:00 p.m. P.S.T. on 15 November 2017.

This Amendment #005 is also raised to issue Addendum #05.

Please see Addendum #05 herein.

The addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

Tender Questions

During the tender period Public Services and Procurement Canada has received various questions from Contractors. The following section lists the questions and the responses. The cost implication of the responses provided are to be included in the tender price.

1. Please specify the “measures” the contractor shall provide to “prevent freezing”?

The measures to prevent the temporary main from freezing shall be based on the prevailing weather conditions during construction. The appropriate measures will be determined by the Contractor.

2. Please specify the specific vault that is required for the backflow, including material type and size (Plastic or concrete box & steel or plastic lid). A Type 67 Water meter box, seems close to the requirements in the response, is this what is intended to be specified?

As per the details on the drawings a pre-cast concrete chamber complete with a steel lid and insulation is required. A type 67 water meter box is an example of an acceptable product

3. If the hydrant is not acceptable to be used for flushing please confirm if there will be an available water source on-site with sufficient flows for chlorinating, flushing, and loading of the lines for testing etc.

Onsite water is available.

4. As previously requested, please confirm the direction of operation of the valves at the hydrants are they to be Clockwise open as per Colwood or Counter-clockwise?

As previously stated the Hydrants shall comply with City of Colwood standards as the local authority having jurisdiction which includes the direction of operation.

5. Previous Questions and Answers seem to indicate that there is to be an extra valve at each hydrant location over and above the ones shown on the drawing, please confirm.

No extra valves are required.

----End of Addendum----