

## QUESTIONS AND ANSWERS

Q1. Drawing A-102 indicates that some of these penetrations appear to be sealed already. What are we supposed to do with them?

A1. Confirm fire seal integrity.

Q2. Drawing A-100 indicates penetration quantities with its related type. Is this the number of penetrations that we have to actually seal?

A2. Yes. It is an estimated number. Refer to unit price table. Q1. Drawing A-102 indicates that some of these penetrations appear to be sealed already. What are we supposed to do with them?

Q3. Who's responsible for paying for the building permit?

A3. The Contractor is required to pay fees and obtain permits required as per Section 01 33 00 par.1.7. For this project a municipal building permit is not required since it is within Federal jurisdiction. However, the Contractor is required to file a Notice of Project as per Section 01 35 29 par.1.3.

Q4. Who's responsible for paying for the fire alarm bypass and who's the fire alarm contractor of the building?

A4. The Contractor is responsible for fire alarm bypass costs if any. Coordinate any disruption to fire alarm system with Owner and PSPC. The fire alarm contractor at this site is:

Natalie Thompson

natalie@drapeau-spk.ca

DRAPEAU AUTOMATIC SPRINKLER CORP.

PH: 613 549-3353 FX:613-549-3354

www.drapeau-spk.ca

Q5. Is any of the abatement part of this contract?

A5. Abatement work is not part of this contract.