



Procurement Hub – Ottawa Office,
Station 9W087, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

Wednesday November 8, 2017

ADDENDUM NO. 1

Subject: **ITT Invitation to Tender No. FP802-170237**

Title: **Slipway Reconstruction, Fishing Harbour of Millerand**

Location: **Magdalen Islands (Québec)**

Closing Date: **Tuesday, November 14, 2017, @ 2pm EST**

Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this **Addendum #1** is to advise potential bidders of the following modifications and/ or questions and answers received from bidders to this tender call:

QUESTIONS and ANSWERS

1. Question from Bidder:

How far are the expansion joints and which material is used?

DFO Answer 01:

Make a longitudinal center saw cut and cross saw cuts at 6 ml c / c. Use an elastomer sealant such as SIKAFLEX or equivalent product.

2. Question from Bidder:

Is steel reinforcement galvanized or not galvanized?

DFO Answer 02:

Not galvanized.



3. Question from Bidder:

It is mentioned in section 01 11 00 page 5 that the recycled plastic decking is provided by the Departmental Representative: Would you have technical specifications of this product, no detail is shown on drawing. This would help us understand installation of this material.

DFO Answer 03:

This is a product of the REPLAST Company and it's made of recycled plastic and its real dimensions are: 3-3 / 8 " x 5-3 / 8" x 144"

<http://www.produitsreplast.com/fr/materiaux/103-madrier-4x6/fiche.html>

4. Question from Bidder:

On sheet 02 Section A: the scale which is indicated 1: 50 does not seem to correspond to the drawing.

DFO Answer 04:

Please use the indicated cotes. Do not take measurements on drawings because of distortion between the original size of drawings and the print format.

All other terms and conditions remain unchanged.

Yours truly,

Lynda Coulombe
Procurement and Contracting Consultant
Matériel and Procurement Services
Financial and Matériel Management Operations
200 Kent Street, 9th Floor, 9W087
Ottawa, ON K1A 0E6
Tel: (613) 993-2839
E-mail: Lynda.Coulombe@dfo-mpo.gc.ca