



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Generator Power System Upgrade	
<b>Solicitation No. - N° de l'invitation</b> EZ899-181569/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2017-11-09
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-020-8216	
<b>File No. - N° de dossier</b> PWY-7-40248 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-11-16</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ly, Ronny(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy020
<b>Telephone No. - N° de téléphone</b> (604) 318-5750 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> CBSA - Douglas POE - Surrey, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EZ899-181569/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

001

File No. - N° du dossier

Buyer ID - Id de l'acheteur

pwpy020

CCC No./N° CCC - FMS No./N° VME

---

Les documents français seront disponibles sur demande

Please find Addendum #1 herein

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

---

## **DRAWINGS**

### **.1 Drawing E-01**

**(1) Revise** Keynote A (for temporary generators) as follows:

“Provide three temporary generators and feeders as shown to maintain loads during shutdown. All temporary generators are to be located outside of the parkade. Allow in tender price for temporary feeder with lengths sufficient to reach from the generators outside to the loads within the parkade. Final locations to be coordinate with Departmental Representative. Coordinate shutdown to tie into existing equipment. All lock-out procedures are to be followed to present feedback to systems.”

### **.2 Drawing E-03**

**(1) Revise** General Note 1 as follows:

“All new penetrations must be scanned or x-rayed prior to coring. Report to be submitted to Engineer and Department Representative showing core locations avoiding all conduits, rebar prior to coring.”

**(2) Revise** General Note 3 as follows:

“All material on the parkade ceiling affected and/or damaged during the work (including fire proofing) must be reinstated upon completion of electrical work, at the electrical contractor's cost, to the original state prior to the work.”

## **SPECIFICATIONS**

### **.1 Add to** Specification Section 01 11 00 – 1.6 Work Sequence the following:

Sentence 1.6.6-

“The Electrical Contractor is to include in their bid price to retain the Facility's Controls Contractor ESC Automation Inc. (ESC) as a subtrade to perform the following work:

1. be present during all scheduled shutdown periods;
2. ensure all controlled systems are shutdown properly before scheduled power shutdown;
3. ensure all controlled systems is operating as normal immediately after power is turned back.

The electrical contractor is to also include in their bid price all costs for commissionaires needed to escort ESC personnel.”

---

- .2 Revise** specification section: 01 11 55 - 1.5.2. as follows:

“All work which generates excessive noise and vibration, including cutting and coring, removal of floor slab shall be executed outside of the normal operating hours, with exception to work conducted in the parkade. Any work in the parkade that would generate excessive noise is to be coordinated and with Departmental Representative. A Notice of Disruption is to be submitted and written approval obtained from Departmental Representative prior to commencement of this work.”

- .3 Revise** Specification Section 01 11 55 – 1.6.1.1.2 to **three** shut-downs.

- .4 Revise** specification section: 01 14 00 - 1.8.1.4 as follows:

“The contractor shall book Commissionaires directly with Commissionaires BC. Book as many Commissionaires as required to satisfy the requirements of .1 above. The Departmental Representative does not need to be involved in the book process.”

- .5 Revise** Specification Section 01 78 00 – 1.2.5 to “sentence deleted”.

**END OF ELECTRICAL ADDENDUM No. 1**

---