

Part 1 ADDENDUM NO.2

1.1 General

- .1 This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2 In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

Part 2 Questions

In the Scope Of Work on House V397 and House V399 , item 8 on both houses it calls to install arctic vents for exhaust fans & HRV exhausts. Our suppliers have advised that there is no arctic vent available for exhausting for exhaust fans and HRV exhausts.

The Vents for the exhaust fans and HRV supply and exhaust ducts are to be designed as per Detail 2 sheet M1.0. No Arctic Plumbing Vents are required for either house on this project.

END OF SECTION