



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Heritage Train Station, Fire Suppression System Replacement – Jasper National Park		
Solicitation No. / N° de l'invitation : 5P420-17-5362/A	Amendment No. / N° de modification de l'invitation : 002	Date: November 15, 2017 Date : 15 novembre 2017
GETS Reference No. / N° de référence de SEAG : PW-17-00800757		
Solicitation Closes / L'invitation prend fin :		
At: 02:00 PM	On: November 16, 2017	Time Zone: Mountain Standard Time (MST)
À : 14h00	Le : 16 novembre 2017	Fuseau horaire : Heure normale des Rocheuses (HNR)
Address Inquiries to / Adresser toute demande de renseignements à : Danny Ahn		
Telephone No. / N° de téléphone : (403) 292-5451	Fax No. / N° de télécopieur : 1-866-246-6893	Email Address / Courriel : Danny.ahn@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date

Amendment 02

This amendment is being raised to answer questions. All such revisions will become part of the Work and the effects shall be included in the Tender Price. All work shall be performed in accordance with the Contract Documents.

A) Questions & Answers

Q1: Is the contractor responsible for the final sign off of the system or would that be done by the consultant?

A1: Contractor is responsible for installation that is in conformance with applicable sprinkler system installation standard as noted in the specification. Contractor is to submit required test and material certificates at project completion. Contractor is not required to engage third party engineer for review or verification of installation.

Q2: Could the contractor use groves fitting rather on the wet system 32 mm and up?

A2: As per specification section 2.2, wet system piping nominal diameter 50mm or less in diameter is to be SCH. 40 and is to utilize threaded fittings. SCH. 10 piping and grooved fittings are only permitted for wet system piping greater than 50mm nominal diameter. This is for aesthetic considerations due the majority of piping being exposed.

Q3: What is the make and model of the fire panel? Does it have room for expansion?

A3: Yes there is capacity for additional zones on the panel. See below for make and model.



All other terms and conditions remain the same.