

---

# **AMENDMENT # 1 REQUEST FOR PROPOSAL**

**Modernization of room controls  
at the Canadian Space Agency (CSA) in St-Hubert**

**Bid Submission Deadline:  
NOVEMBER 23<sup>rd</sup>, 2017 at 2:00 PM (EST)**

Reference: CSA File No. 9F030 – 20170514

*NB:* Please read this Request for Proposal carefully for further details on the requirements and bid submission instructions.



**November 17<sup>th</sup>, 2017**

---

## Amendment # 1

This amendment is put in place for the following reasons:

- Presentation of **addendum 1** of the document "Technical Specifications Mechanical".
  - \* Bilingual document added separately in the attachments.
- Presentation of **addendum 2** of the document "Technical Specifications Mechanical".
  - \* Bilingual document added separately in the attachments.
- The release the first set of questions and answers. (1 question)

### Question 1

Are compatible controllers communicating according to the BACnet protocol, other than those mentioned in the project, accepted in equivalence?

### Answer 1

Electronic and electro-pneumatic accessories must be from Delta Controls as the software has already been pre-approved by the Canadian Space Agency IT services. Any other accessories, compatible or not, will not be accepted.