



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services / Travaux
publics et services gouvernementaux
Kingston Procurement
Des Acquisitions Kingston
86 Clarence Street, 2nd floor
Kingston
Ontario
K7L 1X3
Bid Fax: (613) 545-8067

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services / Travaux
publics et services gouvernementaux
Kingston Procurement
Des Acquisitions Kingston
86 Clarence Street, 2nd floor
Kingston
Ontario
K7L 1X3

Title - Sujet UPS Battery	
Solicitation No. - N° de l'invitation EQ754-181016/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client EQ754-18-1016	Date 2017-11-21
GETS Reference No. - N° de référence de SEAG PW-\$KIN-690-7295	
File No. - N° de dossier KIN-7-48080 (690)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-11-29	
Time Zone Fuseau horaire Eastern Standard Time EST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Rider, Kim (Buyer)	Buyer Id - Id de l'acheteur kin690
Telephone No. - N° de téléphone (613) 545-8739 ()	FAX No. - N° de FAX (613) 545-8067
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EQ754-181016/A
Client Ref. No. - N° de réf. du client
EQ754-18-1016

Amd. No. - N° de la modif.
003
File No. - N° du dossier
KIN-7-48080

Buyer ID - Id de l'acheteur
kin690
CCC No./N° CCC - FMS No./N° VME

Amendment 003 – UPS Battery, is being raised for the following reason:

- 1. Provide a response back from Public Works and Government Services Canada to questions received from bidders.**
-

Q1. Who disposes of batteries?

A1. Contractor.

Q2. How long after receipt of batteries will installation commence?

A2. Installation to be done between 8AM and 6PM on the weekend; delivery can be made during the week after 6PM as building has delivery restrictions and it must be booked with the building.

Q3. Does installation take place in one building? If so, how many floors?

A3. Yes, 1 floor.

Q4. What are (is) the UPS systems for installation of batteries?

A4. UPS Powerware 9355 30 KVA serial number BG192KXX02. 144 batteries at 120w each in the cabinets and 108 batteries at 34w in the main unit.

Q5. Where are the UPS units situated?

A5. 121 King Street West 22nd server room.

Q6. What is the UPS system from which they will be swapped?

A6. The UPS is a 9355 30KVA.

ALL OTHER TERMS AND CONDITIONS OF THIS SOLICITATION REMAIN UNCHANGED.

If your tender has already been forwarded and you wish to revise same, this revision should be faxed and reach the bid receiving area before the closing date. The tender number and the closing date are to be shown on the first page of your fax.