

Q1. Are the quantities that we are expected to carry for relating to Fire stopping and Smoke seal, all listed in the Appendix 1 unit price table?

A1. Yes. Unit Price Table total is only for fire stopping and Smoke seal work.

Q2. Do we need to carry for any Fire stopping and Smoke seal work in the Lump Sum Amount (LSA)?

A2. No. All Fire Stopping and Smoke seal to be included in Unit Price Table.

Q3. There are several items on the Appendix 1 unit price table that indicate an area in the description such as item 18 (ie. Air duct through wall up to 0.4m2).

a. Does the area listed represent the actual area of fire stop/smoke seal that is required? or

b. Are we to provide fire stop/smoke seal to the perimeter of the penetration with the component being the area listed? Please confirm.

A3. The area listed represents the maximum area to be stopped/sealed.

Q4. Item 21 of the unit price table is "Allowance fire stopping to additional unidentified penetration" Please clarify the size/scope we are to allow for this.

A4. This line item No. 21 is to be deleted from the Unit Price Table and not included in bid pricing.

Q5. The Fire Stopping spec section "07 84 00 - 3.7.1 Schedule" lists out items for fire stop and smoke seal. Please confirm that this is general points and is not being used to specify location/quantities requiring fire stop or smoke seal.

A5. This is a general condition to be met during work. Drawings identify the location and quantities of fire stopping and Smoke seal. Any additional quantities must be included as per unit rate table.