



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada

Place Bonaventure,
800 rue de la Gauchetière Ouest
Voir aux présentes - See herein
Montréal

Québec
H5A 1L6

FAX pour soumissions: (514) 496-3822

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Travaux publics et Services gouvernementaux Canada
Place Bonaventure,
800 rue de la Gauchetière Ouest
Voir aux présentes - See herein
Montréal
Québec
H5A 1L6

Title - Sujet Mobilier AMA - SA Furniture	
Solicitation No. - N° de l'invitation EF245-181519/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EF245-18-1519	Date 2017-11-23
GETS Reference No. - N° de référence de SEAG PW-SMTA-160-14602	
File No. - N° de dossier MTA-7-40233 (160)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-11-30	
Time Zone Fuseau horaire Heure Normale du l'Est HNE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Asquino, Carolina	Buyer Id - Id de l'acheteur mta160
Telephone No. - N° de téléphone (514) 496-3549 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

AMENDMENT 002


This amendment is raised to respond to questions received to date on November 22, 2017.

Q2. We have a question concerning the electricity in certain sections.

I am attaching an area of concern, you indicate a power box on the floor and you show the spine panels as electrified, but if we use an electrical whip from the power box we need to electrify the 36 x 48 and 36 x 30 panels.

You specify power poles but in certain areas we can use a base feed (as per this area)

What should we specify?



A2. Only 3 power poles are needed for the entire floor, in one section of the floor. The rest of the connection has to be based feed. See plan.

Questions 3 to 7 are for the 5th floor:

Q3. The code specified for the credenza for closed office room 617-630-655 SPLSSSLXRDDFFCDXX8420 which represent 2 hinge door and 2 drawers is not as illustrated on plan. Please specify your need.

A3. The credenza is for local 534,630 and 655. Submit as code (2 doors & 2 drawers)

Q4. Page 7, line 14 identified as room 517 but we think it is room 534. Please confirm

A4. Yes it is room 534. See revised plan.

Q5. Section 510, 8 stations for the island we suggest 2 base feed instead of 1, please confirm

A5. We are adding a power pole per island .see modified plan

Q6. Section 539, 3 power poles are specified but only 2 would be enough, confirm

A6. We remove one power pole (total 2 power pole per island). See modified plan

Q7. Section 554.1 to 554.1 only one base feed would be necessary not 2 , confirm.

A7. No change, as plan

Questions 8 to 10 are for the 6th floor:

Q8. Do we need to move island for work stations 608.5-608.6-608.7 to attach to the work station 608.3-608.4, or add a base feed.

A8. Yes, you can move the island.

Q9. In the project in general, there are no panels when stations are next to wall. Ex 659.1 to 659.3 Do we need panel for the stations 603.1 -603.2?

A9. Do as plan

Q10. Do we need to add 1 basefeed per island for stations 659.4 et 659.15 because we don't see any.

A10. Yes, see modified plan

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.