



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**Bid Receiving - PWGSC / Réception des soumissions - TPSGC**

11 Laurier St./11 rue Laurier  
Place du Portage, Phase III  
Core 0B2 / Noyau 0B2  
Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

\*\*\* This document contains a security requirement

\*\*\*

\*\*\* Ce document contient une condition de sécurité

\*\*\*

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

Construction Services Division/Division des services de  
construction

11 Laurier St./11 Rue Laurier  
3C2, Place du Portage  
Phase III  
Gatineau, Québec K1A 0S5

<b>Title - Sujet</b> LTDLC Garage Rehabilitation	
<b>Solicitation No. - N° de l'invitation</b> EH901-181236/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> 20181236	<b>Date</b> 2017-11-23
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$FG-356-73597	
<b>File No. - N° de dossier</b> fg356.EH901-181236	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-12-19</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Steele, Harold	<b>Buyer Id - Id de l'acheteur</b> fg356
<b>Telephone No. - N° de téléphone</b> (873) 469-3596 ( )	<b>FAX No. - N° de FAX</b> (819) 956-8335
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EH901-181236

Amd. No. - N° de la modif.  
**004**

Buyer ID - Id de l'acheteur  
FG 356

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME  
R.061511.318

---

**Amendment 004 is issued for the following reasons:**

- To cancel Amendment 003 as it was issued in error;
- To extend the solicitation period from 5 December 2017 to 19 December 2017; and
- To issue Addendum 002 attached herein.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED**

## ADDENDUM N°: 02

PWGSC Project: R.061511.318

**The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.**

### DRAWINGS

#### 1 MECHANICAL

.1 No revision to drawings.

#### 2 ELECTRICAL

.1 E-100 – Lighting & Fire Alarm – Level A (North) – New Layout | Revision 2 | November 15 2017 | Issued with addendum.

.2 E-101 – Lighting & Fire Alarm – Level A (South) – New Layout | Revision 2 | November 15 2017 | Issued with addendum.

.3 E-110 – Lighting & Fire Alarm – Level B (North) – New Layout | Revision 2 | November 15 2017 | Issued with addendum.

.4 E-111 – Lighting & Fire Alarm – Level B (South) – New Layout | Revision 2 | November 15 2017 | Issued with addendum.

.5 E-120 – Lighting & Fire Alarm – Level C (North) – New Layout | Revision 2 | November 15 2017 | Issued with addendum.

.6 E-121 – Lighting & Fire Alarm – Level C (South) – New Layout | Revision 2 | November 15 2017 | Issued with addendum.

.7 E-130 – Lighting & Fire Alarm – Level D (North) – New Layout | Revision 2 | November 15 2017 | Issued with addendum.

.8 E-131 – Lighting & Fire Alarm – Level D (South) – New Layout | Revision 2 | November 15 2017 | Issued with addendum.

### SPECIFICATIONS

#### 1 MECHANICAL

.1 No revision to specification.

#### 2 ELECTRICAL

.1 Section 26 05 00 – Common Work Results for Electrical

.1 Refer to article 1.4.3.1.11 and change to:

Transfer the connection in UPH-1-1 from old **UMH-02-1** to new **UMH-02-1**.  
IMPACT: SHUTDOWN OF ALL EMERGENCY LOADS IN HOTEL AND PARKING (EXEPECT FIRE PUMP). The shut down of UPH-1-1 must be less than 8 hours and must be coordinated with the Hotel at least 60 days in advance. This transfer must be done in presence of division 23 representative, BGIS Representative and departmental representative. Do not remove existing emergency lighting before this point.

## ADDENDUM N°: 02

PWGSC Project: R.061511.318

**The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.**

- .2 Refer to article 1.4.3.1.11.1 and change to:
  - As part of this shut down, retain the services of designated contractor mentioned in 26 24 16.01 – Panelboards Breaker Type to install the breakers in **SB-01-2**. Connect cables in breakers and terminate cables in junction box beside panel, to allow future connection in **SB-01-2**, without requiring full panel shutdown. Lock and tagout affected breakers.
- .2 Section 26 05 28 – Grounding – Secondary
  - .1 Refer to article 1.4.2 and change to:
    - Operation and Maintenance Data: submit operation and maintenance data for **grounding - secondary** for incorporation into manual.
- .3 Section 26 05 31 – Splitters, Junction, Pull Boxes and Cabinets
  - .1 Refer to article 1.4.2 and change to:
    - Operation and Maintenance Data: submit operation and maintenance data for **splitters, junction, pull boxes and cabinets** for incorporation into manual.
- .4 Section 26 05 32 – Outlet Boxes, Conduit Boxes and Fittings
  - .1 Refer to article 1.4.2 and change to:
    - Operation and Maintenance Data: submit operation and maintenance data for **outlet boxes, conduit boxes and fittings** for incorporation into manual.
- .5 Section 26 05 34 – Conduits, Conduit Fastenings and Conduit Fittings
  - .1 Refer to article 1.3.2 and change to:
    - Operation and Maintenance Data: submit operation and maintenance data for **conduits, conduit fastenings and conduit fittings** for incorporation into manual.
- .6 Section 26 12 16.01 – Dry Type Transformers Up to 600 V Primary
  - .1 Refer to article 2.1.1.4 and change to:
    - Insulation class: 220C.**
- .7 Section 26 24 16.01 – Appendix – Electrical Panels
  - .1 Refer to panel BH-02-1, modified and issued with the present addendum.
  - .2 Refer to panel BH-03-1, modified and issued with the present addendum.
- .8 Section 26 28 16.02 – Moulded Case Circuit Breakers
  - .1 Refer to article 1.3.2 and change to:
    - Operation and Maintenance Data: submit operation and maintenance data for **moulded case circuit breakers** for incorporation into manual.

**ADDENDUM N°: 02**

**PWGSC Project: R.061511.318**

**The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.**

- .9 Section 26 28 23 – Disconnect Switches – Fused and Non-Fused
  - .1 Refer to article 1.4.2 and change to:

Operation and Maintenance Data: submit operation and maintenance data for ***disconnect switches – fused and non-fused*** for incorporation into manual.
- .10 Section 26 33 99 – Electric Vehicle Support Equipment (EVSE)
  - .1 Refer to articles 2.3.1.3 and 2.3.1.4 and change to:

Cable – minimum **5.5** meter in length measured coming out of the unit.

Cable management system - self-retracting cable ~~or hanger~~ to keep the cable off the ground when not in use.
  - .2 Add article 2.3.1.6:

***Plugs to be lockable in EVSE unit.***
- .11 Section 26 50 00 – Lighting
  - .1 Refer to article 1.5.2 and change to:

Operation and Maintenance Data: submit operation and maintenance data for ***lighting*** for incorporation into manual.
- .12 Section 26 53 00 – Exit Signs
  - .1 Refer to article 1.3.2 and change to:

Operation and Maintenance Data: submit operation and maintenance data for ***exit signs*** for incorporation into manual.
- .13 Section 26 82 39.01 – Unit Heaters - Electric
  - .1 Add article 2.2.9:

***Integrated Thermostat***