



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Hazardous Bldg Materials Abatement	
Solicitation No. - N° de l'invitation EZ899-181581/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client	Date 2017-11-23
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-8222	
File No. - N° de dossier PWY-7-40244 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-11-27	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: AAFC - Pacific Research Centre - Agassiz, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment #003 is raised to address questions:

Questions and Answers

For Building 28:

Q1. Once fiberglass batt insulation is removed from the perimeter of the main attic space what will be required to create a seal for the attic space?

A1. Based on inspection of the perimeter of the building no soffit vents were identified. As such, not additional work is anticipated to be required in order to seal the main attic space at the perimeter.

Q2. Are all stored items within the main attic space to be removed as part of the abatement work?

A2. Yes. All items are to be either decontaminated and removed for separate disposal/recycling or they are to be removed for disposal as asbestos waste along with the vermiculite. Any porous items which cannot be effectively cleaned (e.g. fiberglass batt insulation or fabric materials) must be disposed of as asbestos waste. See section 01 01 50 General Instructions Part 1.2.2.2.1.1

Q3. Can metal items from the attic be recycled?

A3. Yes but they must be decontaminated prior to removal from the attic.

Q4. Do all surfaces within the attic require vacuuming/cleaning?

A4. Yes. Any surface where dust and debris are present must be cleaned. See sections regarding Cleanup within Sections 02 82 00.01, .02 and .03 Asbestos Abatement

Q5. What, if anything, needs to be done about the attic space within the addition?

A5. Once abatement within the main attic space is complete and the space has been sufficiently cleaned the fiberglass batt insulation separating the main attic space from the addition attic space can be removed to allow inspection of the addition attic space. Any vermiculite or vermiculite contamination discovered within the addition attic space will be dealt with by change order.

Q6. Will the floor boards present in the central part of the main attic space need to be removed in order to remove the vermiculite in the space underneath?

A6. The floor boards will need to be removed to a degree that is sufficient to allow complete removal of the vermiculite, cleaning, and complete inspection of the space upon the completion of abatement.

Q7. What is to be done with the data/electrical cables and panel present in the attic space that service the office space?

A7. The cables will be cleaned as part of the abatement project if they are to remain within the space during the abatement. Perhaps some flooring will need to be left in place in order to access the cables and panel.

Q8. When can the work start and what is the timeline?

A8. As per the specifications – Summary of Work, the Contractor shall perform and complete the Work within six (6) weeks of Contract award.

Q9. Can the door into the main attic space at the North end of the building be used for access/setup/decontamination?

A9. Yes.

For Building 50:

Q10. Will it be necessary to remove the floor boards in the attic space in order to remove all the vermiculite and if so will this affect the structural integrity of the building?

A10. The floor boards will need to be removed to a degree that is sufficient to allow complete removal of the vermiculite, cleaning, and complete inspection of the space upon the completion of abatement. Stantec cannot comment on concerns regarding structural integrity.

Q11. Can AAFC assist with removal of debris and blackberry bushes from the exterior of the building to allow access so that an enclosure can be constructed?

A11. Yes.

All other terms and conditions remain unchanged.