

EQUIPMENT VENTILATION REQUIREMENTS



Toyota Person Carrier

13,000 cfm

Ventilation required to operate underground



Kubota RTV1140CPX

2,400 cfm

Ventilation required to operate underground



Kawasaki MULE 4010

2,500 cfm

Ventilation required to operate underground



EJC 100D Scoop

12,000 cfm

Ventilation required to operate underground