



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Bid Fax: 902-426-1775

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
1869 Upper Water Street, Suite AH 201
Halifax, Nova Scotia B3J 1S9

Title-Sujet North Head Trail, Signal Hill National Historic Site		
Solicitation No. - No. de l'invitation 5P201-17-5116/A		Amendment No./N° de modification de l'invitation 003
Client Ref. No. - No. de réf du client. 591		Date: November 28, 2017
GETS Reference No. - No de reference de SEAG PW-17-00803155		
Solicitation Closes:		
at - à 02:00 PM	on - le November 30, 2017	Time Zone - Fuseau horaire AST - HNA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Tanya Allen – tanya.allen@pc.gc.ca		
Telephone No. - No de téléphone (902) 426-7543		Fax No. - No de FAX: (902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address – Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 003

1.0 Questions and Answers

Q1: The spec calls for 184x184m PT timber for all cribbing work. Will 6x6 Pressure Treated wood suffice for all crib work on the North Head Trail?

A1: Substitution of 6x6 timbers will not be accepted. 8x8 size was chosen to provide a specific riser height. Pressure treatment must be either alkaline copper quaternary (ACQ) or copper azole (CA).

Q2: The helicopter companies that are required to drop material on the trail from the Queen's Battery location expressed concern with weather conditions in doing material lifts at this time of year. Is the expected completion date March 31, 2018 flexible?

A2: The contractor must determine how they want materials to be delivered to site. Helicopters may be used but are not required. Delays in work are covered in the general condition R2865D (2016-01-28) (<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R/R2865D/4>)

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.
