



Materiel and Procurement Services  
200 Kent Street, Station 9W088  
Ottawa, Ontario  
K1A 0E6

November 29, 2017

**Subject: Invitation to Tender: FP802-170264**

**Title: Mactaquac pond recoating and construction**

**Work site location: French Village, New Brunswick**

**Department of Fisheries and Oceans**

**Bid Closing Date: Friday, December 1, 2017**  
**Time: 2:00 pm Eastern Standard Time (EST)**  
**RFP File No: FP802-170264**

**ADDENDUM: No. 1**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#1) is hereby issued.

---

**THE FOLLOWING QUESTIONS WAS SUBMITTED BY A POTENTIAL BIDDER TO THE CONTRACTING AUTHORITY IN RELATION TO THE SUBJECT ITT:**

**Q01: Part 1, Section 1.4 states that power will be available to use for the work on each wing; will power also be accessible to use for a lunchroom/office/storage trailer?**

A01: As per the specification Part 1.4.2 states onus on contractor "PROVIDE TEMPORARY POWER REQUIREMENTS AS NECESSARY FOR OPERATION OF EQUIPMENT". DFO Will Provide 110V where possible.

**Q02: Location of on-site facilities was not discussed at the job meeting. Can you confirm where the successful bidder will set-up? Will they be able to access the washrooms inside the hatchery or will they provide their own?**



A02: The successful bidder will be allowed to utilize the entire lower fenced portion of the seasonal "Visitor" Parking Area. Contractor to provide portable washroom facility.

**Q03: How deep are the tanks?**

A03: Please refer to the specification. (1370 mm)

**Q04: Can Sand bags be used to block off the fish trap doors?**

A04: Specification 1.9 States "Provide Water Barrier Behind Fish Trap door During Coating Application". The last time the tanks were recoated the contractor used plywood with a neoprene gasket and braced it in place.

**All other Terms and Conditions for this requirement remain unchanged.**

**Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.**

Regards

**Julie Michelle Tremblay**  
Senior Contracting Officer  
Material and Procurement Services  
[Julie.Michelle.Tremblay@dfo-mpo.gc.ca](mailto:Julie.Michelle.Tremblay@dfo-mpo.gc.ca)  
Téléphone | Telephone 613-998-1614  
Télécopieur | Facsimile 613-991-4545  
200 Kent Street  
Ottawa, ON K1A 0E6  
Fisheries and Oceans Canada  
Government of Canada

---

***RECEIPT ACKNOWLEDGED***

**Name of Company** \_\_\_\_\_

**Signature** \_\_\_\_\_