

McElhanney

WATER
SURVEY
VANCOUVER



FINAL REPORT
FOR THE
REVIEW AND
PROFESSIONAL CERTIFICATION
OF
ENVIRONMENT CANADA'S HEAVY DUTY
CABLEWAY DESIGNS



McElhanney

20 June 2002
Our File: 2111 01745-1

Environment Canada
Meteorological Service of Canada
Water Survey Division
~~1200 West 73 Avenue - Suite 700~~
Vancouver BC V6P 6H9

Attention: Curt Naumann, M.A.Sc., P.Eng.
Project Engineer

Dear Sir:

Review and Professional Certification of Environment Canada's Heavy-Duty Cableway A-Frame Designs.

McElhanney Consulting Services Ltd. is pleased to submit this report for the Review and Professional Certification of Environment Canada's Heavy-Duty Cableway A-Frame designs.

This report identifies the heavy-duty cableway design criteria, the structural design methodology and a summary of the results of the analysis.

The report includes a copy of the structural design calculations and a complete set of hard copy AutoCAD Drawings Nos. 3136-1 to 3136-10 with Drawing Nos. 3136-1 to 3136-6 inclusive, as well as 3136-9 being professionally certified.

1.0 BACKGROUND

Environment Canada installs water monitoring stations throughout the Pacific and Yukon Region for the purpose of collecting and storing discharge, water level, and sediment data. The structures used for collecting the data vary depending on the physiographic site conditions, and range in complexity from simple in-stream hydraulic structures such as weirs to more complex structures such as metering bridges and hydrometric cableways.

Hydrometric cableways are used on rivers where the water is too deep or the flow is too fast to permit the safe collection of the water data by wading measurements.

Environment Canada, Pacific and Yukon Region, currently uses two different cableway A-Frame designs. Light-Duty Cableway A-Frame Designs are used for short spans up to 150 metres and A-Frame heights up to 5.0 metres. Heavy-Duty Cableway A-frame Designs are used for spans between 150 and 300 metres and A-frame heights from 1.0 to 10.0 metres. They are also used on shorter spans where A-Frame heights exceed 5.0 metres. Spans greater than 300 metres are custom designed.

continued....

2111UOB101745-11062002R1

Return to
Curt Naumann.
201 - 401 Burrard St
Vancouver.



Environment Canada is currently reviewing the cableway A-Frame designs based on the revised design criteria and therefore has requested that the Heavy-Duty Cableway A-Frame Designs be professionally reviewed and certified.

2.0 SCOPE

The scope of this project involves the following tasks:

1. A review of Environment Canada's Heavy-Duty Cableway A-Frame designs, (Drawings Nos. 3136-1 to 3136-10 inclusive). Drawings Nos. 3136-7, 3136-8, and 3136-10 pertain to footing details and other various A-frame components that will not be reviewed at this time.
2. Professional Certification of the existing AutoCAD drawings (Drawing Nos. 3136-1 to 3136-6 inclusive, as well as 3136-9).
3. Submission of a letter report highlighting: the hydrometric cableway design criteria, the structural design methodology, the structural design calculation notes and a full set of drawings.

3.0 HYDROMETRIC CABLEWAY DESIGN CRITERIA

3.1 General

Environment Canada's Hydrometric Cableways are designed based on the maximum design loads being applied to the main cable and A-frames. These result when the meter cable catches a debris snag and is pulled downstream. The distance and angle at which the load is applied is based on the length of meter cable and the type of sounding reel used. The design philosophy is such that the meter cable will break before the main cable, towers or anchorages fail.

The snagging of floating debris on the meter cable may cause a substantial downstream load on the cable, which would be transmitted to the cableway A-frames. This causes a large downward force on the downstream leg of the A-Frame and may cause a negative (lifting) force on the upstream leg. Calculations used to compute loads on A-Frames and their footings are based on the following design criteria.

3.2 Heavy Duty Cableway Design Criteria

- Applicable for spans from 150 to 300 metres and A-Frame heights from 1.0 to 10.0 metres. Also used on shorter spans where A-Frame heights exceed 5.0 metres;
- All nuts and bolts shall be ASTM A325, Type 2, Galvanized;
- For use in areas not subject to heavy ice or ground snow loads over 4.5 kN/m²;

continued....

2111JOB01745-1062002R1



- Wind Loads up to 0.5 kN/m^2 ;
- Marker line consists of $\frac{1}{2}$ " diameter wire rope, Weight = 0.44 lbs/ft, Breaking Strength = 11.8 tons = 23,600 lbs;
- The main cable – Environment Canada states in the "Safety Guide-Construction and Operation of Stream-Gauging Cableways", Fisheries and Environment Canada, 1977, that a factor of safety of 5 must be used for the design of the main cable. Also that the thimble and clip connections develop a maximum of 80% of the ultimate strength of the cable. The USGS, "Streamgauging Cableways", Open File Report 91-84, recommends a factor of safety of 5 for the main cable. However, appropriate design factors for static cable have been suggested as 3 to 4 in "Machinery's Handbook", 21st edition, page 84, and 3 to 5 in "Marks, Handbook for Mechanical Engineering", 8th edition, pages 10 to 35.

For normal operating loads, i.e., cable car with two men and a sounding reel, we recommend a safety factor of 5. For the extraordinary loading occasioned by the breaking of the snagged meter cable, a safety factor of 3 is adequate.

The recommended main cable wire rope used for spans from 150 to 300 metres consists of 1" diameter, 6 x 19, IWRC, Improved Plow, right regular lay galvanized wire rope. Weight = 1.76 lbs./ft, Breaking Strength = 40.8 Tons = 81,600 lbs.

- Design loads for the main cable comprise the following:
 1. Uniform load based on the mass of main cable, (1.76 lbs/ft)
 2. Concentrated load of 2250 lbs carried by the cable car consists of:
 - Breaking Strength of meter cable (snag load) = 1600 lbs.
For the purpose of estimating the vertical component of the snag load, it was assumed that the D Reel was used, having a $\frac{1}{8}$ " diameter cable, cable length = 175 ft. and acting at 20 ft. above the water surface. The vertical component of this snag load = 182 lbs.
 - Weight of the Heavy duty cable car = 200 lbs. Height of car = 2.0 metres
 - Weight of the sounding reel = 50 lbs.
 - Weight of occupant(s) = 400 lbs.

The total design vertical component when the snag load is considered = 832 lbs.

- The main cable designed such that the unloaded sag is set at 2% of the span.
- The review has been based on the tops of the A-Frames being at the same elevation;
- The Aircraft Marker Spheres that are used on longer spans (greater than 150 metres) have a diameter of 30 inches and are made of fiberglass. The spheres weigh approximately 19 lbs each. The Ministry of Transport requires one sphere every 45 metres.



- The angle of the main cable as it approaches the anchor is assumed to be 30 degrees below horizontal.

4.0 STRUCTURAL DESIGN METHODOLOGY

The following structural design methodology and various loading conditions were used to review the Heavy Duty Cableway A-Frames.

1. The design load, including the snag load, applied at mid-span acting vertically downward;
2. The design load applied at mid-span with the 1600 lbs breaking strength of the meter cable (snag load) acting downstream.
3. The design load applied at $\frac{1}{4}$ of the span acting vertically downward;
4. The design load applied at $\frac{1}{4}$ of the span with the 1600 lbs breaking strength of the meter cable (snag load) acting downstream.
5. The design load applied at mid-span without the snag load.

The above loading conditions were analyzed for a 150 metre and a 300 metre span.

5.0 SUMMARY OF RESULTS

The 150 metre span was initially analyzed using a 1" diameter IWRC, IP, wire rope under the above loading conditions. The results of the analysis are summarized in Table 1.

Table 1. Summary of Analysis for 150 m Span, 1" Wire Rope, BS = 81,600 lbs.

Loading Condition (See Section 4.0)	Load (lbs)	H (lbs)	Cable S.F.	A-Frames (With Snow)
1. $\frac{1}{2}$ span, vertically down	2,250	20,020	4.1	O.K.
2. $\frac{1}{2}$ span with snag load	832	20,020	4.1	O.K.
3. $\frac{1}{4}$ span, vertically down	2,250	18,959	4.3	O.K.
4. $\frac{1}{4}$ span with snag load	832	18,959	4.3	O.K.

The results show that under the design loading conditions, the A-Frames meet the design criteria with the snow load applied. The main cable has a factor of safety ranging from 4.1 to 4.3, which is acceptable.

The 300 metre span was then analyzed using the 1" IWRC, IP, wire rope, under the above loading conditions. The results are summarized in Table 2.

continued....

2111JOBW1745-11062002R1



Table 2. Summary of Analysis for 300 m Span, 1" Wire Rope, BS = 81,600 lbs.

Loading Condition	Load	H	Cable	A-Frames
(See Section 4.0)	(lbs)	(lbs)	S.F.	(With Snow)
1. $\frac{1}{2}$ span, vertically down	2,250	24,317	3.4	O.K.
2. $\frac{1}{2}$ span with snag load	832	24,317	3.4	O.K.
3. $\frac{1}{4}$ span, vertically down	2,250	22,608	3.6	O.K.
4. $\frac{1}{4}$ span with snag load	832	22,608	3.6	O.K.
5. $\frac{1}{2}$ span no snag load	650	15,436	5.3	O.K.

The results show that under the design loading conditions, the A-Frames meet the design criteria with the snow loads applied.

The diameter of the main cable was increased to $1\frac{1}{4}$ " and the 300 metre span was then analyzed under the above loading conditions. The results are summarized in Table 3.

Table 3. Summary of Analysis for 300 m Span, $1\frac{1}{4}$ " Wire Rope, BS = 141,000 lbs.

Loading Condition	Load	H	Cable	A-Frames
(See Section 4)	(lbs)	(lbs)	S.F.	(With Snow)
1. $\frac{1}{2}$ span, vertically down	2,250	30,592	4.6	Remove Snow from 10 m Towers
2. $\frac{1}{2}$ span with snag load	832	30,592	4.6	Remove Snow from 10 m Towers
3. $\frac{1}{4}$ span, vertically down	2,250	28,803	4.9	Remove Snow from 9 & 10 m Towers
4. $\frac{1}{4}$ span with snag load	832	28,803	4.9	Remove Snow from 9 & 10 m Towers
5. $\frac{1}{2}$ span no snag load	650	-	5+	

The results show that under the design loading conditions, the snow load should be removed from the 9.0 and 10.0 m A-Frames prior to use. The main cable has a factor of safety of 4.6 or greater, which is acceptable.

6.0 SUMMARY AND RECOMMENDATIONS

The existing Heavy-Duty Cableway A-Frame designs meet the revised hydrometric design criteria for spans between 150 and 300 metres, with the following conditions:

continued....

2111JOB01745-1062002R1



Page 6
Our File: 2111 01745-1

1. It is recommended that the wire rope used on the Heavy Duty Cableways for spans between 150 metres and 300 metres should be 1" diameter, 6 x 19, IWRC, Improved Plow, right regular lay, galvanized wire rope.
2. It is also recommended that if using the 1¼" main cable, the snow be removed from the platforms on the 9.0 metre and the 10.0 metre A-Frames prior to use, or to consider redesigning the platforms to allow snow to pass through without accumulation.

As noted, these designs incorporate certain specific conditions such as the tops of the A-Frames being at the same elevations, and the main cable backstays being at 30° to horizontal. Great accuracies of analysis for actual conditions should not be counted on.

We have enjoyed working with you on this project and we trust this report provides the information that you require and that it meets the expectations outlined in the project scope.

Yours very truly,

McELHANNEY CONSULTING LTD.

A handwritten signature in black ink, appearing to read "A.A. Williams".

A.A. Williams, P.Eng.
Senior Bridge Specialist
Vancouver Region Engineering

e-mail: awilliams@mcelhanney.com
AAW.lfd

APPENDIX A
STRUCTURAL DESIGN CALCULATIONS



SUBJECT	MOE HEAVY DUTY A FRAMES	DESIGN DATE	CHECK DATE	JOB NO.	PAGE

INDEX

GENERAL CONDITIONS	G-1
TOWER	T-1
CABLE CALCULATIONS	1
Summary	18
ANCHOR PLATE & TIE	AP-0
TOWER FOOTINGS	F-1
LADDER	L-1



SUBJECT	ENVIRONMENT CANADA CABLE & A. FRAME CRITERIA	DESIGN <i>asw</i>	CHECK	JOB NO.	PAGE
DATE		DATE			G-1

Spans 150 m to 300 m

Start with 2% sag of unloaded cable.

Backstay 30° to horiz.

Towers:- 1m to 10m in 1m incr.

Cables 1"

Stretch to incl. backstays for 6m tower

Load:	Car	200 #	Meter line 175' long
	Reel	50	1600 # B.S.
	2 men	400	Car 20' above water
	Basic Load	<u>650</u>	
		<u>1600</u>	
		<u>2250</u>	

Structural Steel - G40.21-11 GRADE 350 W GALV.

Ground snow load = 4.5 KN/m² x .6 = 2.7 = 56 psf

1" IWRC 1.76 psf B.S. = 40.8 tons = 81.6 k

1 1/4" 2.75 70.4 = 141 k


1" EA = 18500 x .7854 = 14530 1 1/4 EA = 18500 x 1.227 = 22700

ENVIRONMENT CANADA DWS65 3136-1 to 3136-10
DWS 2812-R2

Handbook of Rigging Lossageg 14th ed. 111 3rd Ed.



SUBJECT	ENVIRONMENT CANADA CABLEWAY - BASIC THEORY	DESIGN	Rev	CHECK	JOB NO. 241	PAGE
		DATE	Nov 05 01	DATE	01745-1	G-2



Stretch in Cable based on 6m high towers
 $= 39' \times 2 + 5\text{m} = \text{Span} + 78'$
 $N = \text{cable wt./foot}$

Tower top supported by aux. tie backs ----
 \therefore Tension in cable constant all the way. $T = H$

Load to Tower = Vert. reaction from susp. cable V_R
 $+ H \tan 30^\circ$ from back span

Note: This should be $H \sin 30$ but to account for vertical into tower from Aux. tie back cables use
 $H \tan 30^\circ$

See P. G-3

Tension to Anchor Rod (in ground) = $H / \cos 30^\circ$


SUBJECT	DESIGN <i>and</i> DATE <i>Dec 14 01</i>	CHECK DATE	JOB NO. 2111 01745-1	PAGE 6-3
TIE BACK EFFECT				

P. 16 Max Cable Tens = 30.59

Assume $T = H$

$\alpha = 6^\circ$ for some cases.

$\beta = 30^\circ$



$$R_{Ax} = 2T \sin \frac{\alpha + \beta}{2}$$

$$H_1 = 2T \sin \frac{\alpha + \beta}{2} \cdot \sin \beta - \alpha$$

$$\text{Tower} = 2T \sin \frac{\alpha + \beta}{2} \cos \beta - \alpha$$

If $\alpha = 6^\circ$ & $\beta = 30^\circ$

$$R_{Ax} = 0.62 T$$

$$\text{Tower} = 0.56 T$$

$$H_1 = 0.25 T - \text{taken by Aux. Tie Back}$$

i adds to Tower load.
And adds to T for pull on anchor.

\therefore Design anchor for $H/\cos\beta$.



SUBJECT	DESIGN <i>as</i> DATE <i>May 22 02</i>	CHECK DATE	JOB NO. <i>2111</i> <i>01745-1</i>	PAGE <i>G-4</i>
<i>Geom A Frame Parts</i>				



Dwg. 4 - A FRAME TOP

Given L Find S

$$S = 560 + \frac{2L}{\sqrt{26}}$$

L	S	B	<i>+2435</i>
1000	952	642	<i>= +70</i>
2000	1344	1034	1104
3	1737	1427	1497
4	2129	1819	1889
5	2521	2211	
6	2913	2603	2673
7	3306	2996	3066
8	3698	3388	3458
9	4090	3780	3850
10000	4482	4172	4242

BRACE $B = S - 155 \times 2$
 $= S - 310$





SUBJECT	DESIGN <i>Red</i>	CHECK	JOB NO. 2111	PAGE
DATE	<i>Nov 06 01</i>	DATE	01745-1	T-1

HSS 127 x 127 x 4.78 for all frames 50 Fy
1m to 10m.

$$\text{HSS } 5 \times 5 \times 0.188 \quad A = 3.53 \text{ in}^2 \\ I = 13.5 \\ S_M = 5.39 \\ r = 1.95$$

$$\text{Cap'g per leg } \frac{Kl}{r} \quad K = 1.0 \text{ (most probable)} \\ = \frac{1 \times 32.8 \times 12}{1.95} = 202$$

$$F_a = 3.73 \quad \text{Cap'g} = 3.73 \times 3.53 = \underline{\underline{13.17}} \text{ k/leg. Comp.}$$

$$\text{COMPACT? } \frac{255}{150} = 3.6$$

$$\text{Unsupp.} = (5 - 2 \times 1.88) / 1.88 = 24.6$$

$$\therefore \text{Compact } F_a = .66 \times 50 = 33$$


$$\therefore \text{Cap'g in bending} = 33 \times \frac{5.39}{12} = \underline{\underline{14.82}} \text{ k}$$

$$\text{Sway 4m} = 13' \quad \frac{Kl}{r} = \frac{1.2 \times 13 \times 12}{1.95} = 97 \quad F_a = 6.0 \quad \text{Cap'g} = 56 \text{ k}$$

$$\text{BOLTED Conn.} \quad 8-16\phi \text{ Bolts} \quad A = 8\phi = 8 \times 3.068 = 24.51 \text{ in}^2 \quad (3.53)$$

$$I_{\frac{8 \text{ Patts}}{8 \text{ Patts}}} = 90 = 3.54'' \quad I = (.3068 \times 3.54^2) 6 = 23.11 > 13.5$$

\therefore OK conn is stronger than HSS



SNOW ON PLATFORM Dwg WSC 3136-9 2m x 1.5m

$$\text{Area} = 6.56' \times 4.92' = 32.3 \text{ ft}^2 \quad \text{Snow Grd Load} = 4.5 \times 0.6 = 2.7 \text{ KN/m}^2 \\ \text{Load} = 32.3 \times 56 = 1,822 \text{ k} = 0.91 \text{ k/leg} \\ M = 0.91 \times \left(\frac{6.56}{2} + \frac{5}{12 \times 2} \right) = 3.17 \text{ k/leg.}$$



SUBJECT	DESIGN DATE	CHECK DATE	JOB NO. 2111 01745-1	PAGE T-2
Heavy Duty A-frames	Nov 07 01			

CAPACITY per LEG IN COMP. HSS A = 3.53 r = 1.95 50 Fy

Length	K/L	F _a	Cab ² /k	Spread
10m	32.8'	202	3.73	14.7
9	29.5	182	4.50	13.2
8	26.3	162	5.68	11.8
7	23.0	141	7.49	10.4
6	19.7	121	10.2	8.6
5	16.4	101	14.6	5.5
4	13.1	81	20.4	3.0
3	9.84	61	23.5	0.0
2	6.56	40	26.8	0.0
1	3.28	20	30.0	0.0

SWAY FORCES FROM SWING LOAD


8m Tower is not braced Dwg. 3136-2

Unbraced = 4m = 13'

$$P.14 \text{ Horiz} = 1600 \times \frac{3}{4} = 1200 \text{ # @ Tower}$$

$$M/Lag = \frac{1200}{2} \times \frac{13}{2} = 3.9 \text{ in./connection}$$

$$f_b = \frac{3.9 \times 12}{5.27} = 8.8 \text{ ksi } F_a = 33 \quad 0.27 \\ \text{To P.14}$$



$$\text{Horiz. 10m Tower} = \frac{4172 \text{ in.}}{\text{HSS } 63.5 \times 63.5 \times 3.18} \quad r = 24.4 \\ \frac{KQ}{r} = \frac{1 \times 4172}{24.4} = 171 - 0.1\%.$$



SUBJECT	DESIGN <i>Adel</i>	CHECK	JOB NO.	PAGE
TOP - HEAVY DUTY A-FRAME	DATE Jan 09 02	DATE	01745-1	T-3

Load to Main Shear . P.12 = $19.66^k = 20^k$ Dwg 3164-4
Rev 0

On HSS $127 \times 127 \times 4.78$ = $5 \times 5 \times 0.188$ $5 = 5.39$


As a beam - Span .500 = $20''$ $M = 19.66 \times \frac{20}{4} = 98''^k$
 $f_b = \frac{98}{5.39} = 18 - \text{OK.}$

Shear $19.66/4 = 5^k/\text{web of } 5'' \times 0.188$ $f_s = \frac{5}{5 \times 0.188} = 5.32 \text{ OK.}$

Bearing Under Shear $20/2 = 10^k$ on 1 web. $5'' \rightarrow$
 $f_p = \frac{10^k}{.188(5 + ?)} = 10.6 < .75 \times 50$

Back Stay Eye bolt. P. 6-3 $H_i = 0.25T = 0.25 \times 35 = 8^k$ P. AP-1

5 Weld $\frac{3}{16} = 2.4^{\prime\prime}/\text{in}$ 2 sides OK in 1"



Sheave Diameter. Hndbk P.65

200# Sheave wire $1\frac{1}{4}'' \therefore \frac{200}{1.25} = 6.4 - \text{OK - not running}$

Also by on sheave $\phi = \frac{T}{rd} = \frac{35}{3'' \times 1\frac{1}{4}''} = 9.3 \text{ ksi} - \text{OK not running.}$

Sheave Pin $39\phi = 1.54'' R = .62 \times 10.59 = 20^k$

Shear Cap. = $2 \times 10 \times 1.50 \times \frac{25}{4} = 85^k - \text{OK.}$

Bearing on saddle $2 \times 60 \times \frac{3}{4} \times 1.50 = 135^k$



SUBJECT	NOE Mid Span 150m	DESIGN	Check	JOB NO 2111	PAGE
LOADED VERT. SWING	2250#	DATE	DATE	01745-1	1

$\text{Seg}_{DL} = 2\% \text{ of span } P = 650 \text{ ft} + 1600 \text{ Swng} = 2250 \text{ ft}$ $\text{Cable} = 1.76 \times 492 = 866$

$\text{Use 6m tower for stretch} = 2 \times 12 = 24 \text{ m} + \text{ft} 17.72 = +78' \text{ Cable for stretch} = 492 + 78 = 570$

INCLUDES STRETCH on 6m high deckings.

Mid Span 1 2 3 4 5

SPAN	150m 492					$H_{DL} = \frac{i(2LL+866)}{8549}$
Seg _{DL}	9.84'					
H _{DL}	5412					$\text{Str} = \frac{f_i \times \text{kips}}{18500 \times .7854}$
Lgth	492.52					$= (493 + 78)$
Wt/cb	866					
P/W	2.60					
	1.1466					
Seg _{LL}	1.44					
Seg _{DL+LL}	11.29					
H _{DL}	29230	17290	21133	19351	20641	
H _{LL}	23818	11878	15721	13939	15229	
Stretch	0.94	0.47	0.62	0.55	0.60	
New Lgth	493.46	492.99	493.14	493.07	493.12	
1/2 lgth.	246.73	246.49	246.57	246.53	246.56	
defln @	19.00	15.60	17.00	16.00	16.50	
Seg (03)	0.77	0.63	0.688	0.645	0.665	
H	17290	21133	19351	20641	20020	
Lgth'	246.74	246.50	246.59	246.53	246.56	
V ₋	1552	1557	1554	1559	1559	
V ₊	1119	1124	1121	1126	1125	
2250	Liv load	2238	2248	2242	2252	2250
3116	ELect	3104	3114	3108	3118	3118



SUBJECT	150m Mid Span 150m LOADED + SNAG (SLOPED) 1"φ	DESIGN DATE	CHECK DATE	JOB NO.	PAGE
				01745 1	2

$$P = \text{Vert. Load} = 650 + 182 = 832 \text{ #} : P/W = 832/866 = 0.96$$

$$\text{Cable } \frac{866}{\Sigma} = \frac{866}{1698} = 0.51$$

Including
Stretch.

#1 #2 #3


SPAN	150 m 492'					$H_{\text{max}} = i \left(\frac{2LL + sag}{8500} \right)$
Sag L.L.	9.84					
H_{LL}	5412					
Lgth	492.52					
Wt/cable	866					
P/W	0.96					
Sag L.L.	-1.306					
	1.29					
Sag D.L.	11.13					
H_{DL}	13980	10913	11994	11477		
H_{LL}	8568	5501	6582	6065		
Stretch	0.34	0.22	0.26	0.24		
New Lgth	492.86	492.74	492.78	492.76		
1/2 lgth.	246.43	246.37	246.39	246.38		
defln (1)	14.2	13.0	13.6			
Sag (2)	1.22	1.11	1.16			
H	10913	11994	11477			
Lgth'	246.43	246.36	246.39			
849	V	846	850	851		
416	V _R	413	417	418		
832	Lv load	826	834	836		
1698	Eload	1692	1700	1702		



SUBJECT	MID SPAN 150 m SNAG LOAD = 10m TOWER	DESIGN DATE	CHECK DATE	JOB NO. 2111 01745-1	PAGE 3
---------	---	----------------	---------------	-------------------------	-----------

Motor line 1600# B.S.

175' long Water to cable = 20'




$$\begin{array}{r} \text{Vert. : } 851 \\ + 1600 \\ \hline 2451 \end{array}$$

$$\begin{array}{r} \text{Cable : } 433 \\ - 1265 \\ \hline 12513 \end{array}$$

For 1600# pulling laterally
at mid span sag (horiz; dist.)
will approximate 2250 # at
mid span from P. L 16.5 ft

$$H = 20,020 \#$$



$$\therefore \text{Vert. load to tower} = V_2 = 851 \#$$

$$\text{From } H \cos 30^\circ = 20,020 \tan 30^\circ = 11,662$$

$$\text{Vert. to Tower} = 12,513$$

$$\begin{array}{l} \text{10m Tower} \\ = 33' \\ \text{Trend} = 4.482 \text{ m} \\ = 14.70' \end{array}$$

$$M.t. \text{ Tower} = 1600 \# @ \text{mid span} = 800 \#/ \text{tower}$$

$$\text{Hor. Snag load per to tower top.} \times 33' = 26.4''$$

$$\text{Load to leg} = \frac{12,513}{2} \pm \frac{26.4}{14.7} = 6.26 \pm 1.80 = 8.06 \text{ or } 4.46$$

$$\text{Comb.} = \frac{8.06}{13.17} + \frac{0}{14.82} = 0.61$$

P.T-1

$$\text{With Snow} \quad \frac{8.06 + 0.91}{13.17} + \frac{3.17}{14.82} = 0.68 + 0.21 = 0.89 \text{ OK.}$$

10m Tower

CABLE $H = 20,020 \text{ vs } 81.6 = 4.1 \text{ S.F.}$



SUBJECT 150m $\frac{1}{4}$ SPAN
LOADED + Vert Snag. 1"φ

DESIGN Q2d
DATE Oct 29 01


CHECK
DATE

JOB NO.

PAGE

4

Ch 2250
866
3116



Stretch based on $2 \times 39 + 182 = 571'$

SPAN	369'	123'					$Str = \frac{11.138 \times 571}{18550 \times .7854} = 0.44$
Sag dL	9.84						$= 99.2 \times .52 / 492.96$
H_dL	5412						
Lgth	492.52						
Wable	866						
P/W	x						
Sag dL							
H_dL	16550						
H_LL	11138						
Stretch	0.44						
New Lgth	492.96						
1/2 lghth.	-						
defn @	-13.0	413.0					
Sag ③	1.58	0.176					
H	18959	18959					
Lgth	369.25	123.69					
V_L	9.93	1896					
V_R	-343	-2112					
2250	Liv load	2239					
3116	Elod	3105					
	Lgth	492.94 vs					
		492.96					

$$\begin{aligned} \text{Load To} \\ \text{TOWER} \\ \text{SPAN} = 2112 \\ \text{Pktg. } 18959 = 10946 \\ \tan 30^\circ = 13058 \\ = 6529.16 < 13.17 \end{aligned}$$

Tension = 18.959

vs 81.6
S.F. = 4.3

ADD SNOW
 $6.5 + 0.91 + \frac{3.17}{13.17} = 14.82$

$0.56 + 0.21 = 0.78$



SUBJECT	150 m	4 Journ	DESIGN	Adair	CHECK	JOB NO.	PAGE
LOADED + SNAG (5/8"dia)	1"φ		DATE	Oct 29 01	DATE		5

$$P = \text{VEAR. LOAD} = 650 + 182 = 832 \quad 832 / 866 = \\ \text{Cable} = \frac{866}{1698}$$

1600 ft Downstream.

SPAN	369	123					$\text{St} = \frac{5248 \times 571}{18550 \times 7854} = 0.21$ <u>492.52</u> <u>492.73</u>
Sag d.L.	984						
H d.L.	5412						
Lgth d.L.	492.52						
Wable	866						
P/W	x						
Sag d.L.							
Sag d.L.							
H d.L.	10660						
H L.L.	5248						
Strtch	0.21						
New lghth	492.73						
1/2 lghth.	-						
defn @	-11.0	+11.0					
Sag ③	2.81	0.312					
H	10660	10660					
Lgth *	369.22	123.49					
V.	643	-845					
V.	7	1062					
832	Loaded	838					
1698	Elod	1705					
Lgth	492.73	= 492.73					



SUBJECT 150m 45SPAN LOAD + Hor. SNAGS.	DESIGN <i>Raw</i> DATE Nov 07 01	CHECK DATE	JOB NO. 2111 01745-1	PAGE 6
---	-------------------------------------	---------------	-------------------------	-----------

$$\text{Vert. to tower} = 1062 + H \tan 30^\circ$$

$$\text{Seg} = 13.6' \quad H = 11477$$

$$1600 \text{ ft laterally} \div 2250 \text{ at mid span} \\ = H = 20.020 \text{ with seg } 16.5 \quad \text{See P. 3}$$

$$\text{Vert to tower} = 1062 + 20.020 \tan 30^\circ \\ = 12.62^k$$

$$H \text{ to tower } 1600 \times \frac{1}{4} = 1200 \text{ ft tower tip}$$

$$10m \text{ Tower } H = 1.2 \times 33' = 39.60$$

$$\text{Load to tip} = \frac{12.62}{2} \pm \frac{39.60}{14.75} = 6.31 \pm 2.69 = 9.00 \text{ or } 3.62$$

$$\text{Comb} = \frac{9.00}{13.17} + \frac{0}{14.82} = 0.68 \quad \text{OK } 10m \text{ Tower}$$

$$\text{With Snag} \quad \frac{9.00 + 0.91}{13.17} + \frac{0.17}{14.82} = 0.75 + 0.21 = 0.97 \quad \text{O.K.}$$

$$\text{Cable} \quad H = 20.020 \text{ vs } 81.6 \quad S.F. = 4.08$$



SUBJECT	300m Mid Span	DESIGN	CHECK	JOB NO.	PAGE
LOAD + VERT SAGS.	1"φ	elred	DATE Oct 30 01		7

$$\text{Vert. load} = 650 \#$$

$$\text{Sag Vert.} = \frac{1600}{2250 \#} \text{ ft}$$

$$\text{Cable: } 984 \times 136 = \frac{1732 \#}{3982} \\ \frac{1}{2} = 1991$$

$$L_{\text{th}} \text{ for stretch} = 984 + 2 \times 39 = 1062'$$

$$H_{\text{DL}} = 984 (2 \times 2250 + 1732) / 8 \times 2250 = 34389$$

$$\text{Stretch} = (H - 10.824) \times 0.000001 + 0.01 / 2 =$$

1/2 Lth.

SPAN	984'							
Sag _{DL}	19.68							
H _{DL}	10824							
Lgth	985.05							
Wash	1732							
P/W	1.30							
Sag _{LL}	-1378							
Sag _{LL}	2.71							
Sag _{DLL}	22.39							
H _{DLL}	34389	29586	23154	24317				
H _{LL}	23565	18762	12330	13493				
Stretch	1.72	1.37	0.90	0.97				
New Lth	986.77	986.42	985.95	986.04				
1/2 lth	193.39	493.21	492.98	493.02				
defl _n (①)	-26	-32	-31.5	-31.5				
Sag(③)	7.80	2.30	3.19	2.19				
H	29586	23154	24317	24317				
Lgth'	492.70	493.068	493.033	493.033				
1991	V-	1996	1989	1990	1990			
1125	V+	1131	1073	1124	1124			
2250	Liveload	2262	2146	2248				
3982	Eload	3992	3878	3980				



SUBJECT	300m MID SPAN LOAD + SNOW SWAG.	DESIGN 2201 DATE Dec 14 01	CHECK DATE	JOB NO.	PAGE 7A
---------	------------------------------------	-------------------------------	---------------	---------	------------

$$\text{Vert. to tower} = 1990 \\ + 24317 \tan 30 = \frac{14040}{16.030}$$

$$\text{Load per } 1\phi = \div 2 = 8.02 < 13.17 \text{ OK.}$$

With snow $\frac{8.02 + 0.91}{13.17} + \frac{3.17}{14.82} = 0.68 + 0.21 = 0.89$
OK to 10m toward

Tension in 1φ Cable = $24.3 \text{ kN} / 81.6 \text{ SF} = 3.36$



SUBJECT	300m Mid Span	DESIGN	Q.D.W.	CHECK	JOB NO. 211)	PAGE
LOAD ONLY	1"φ	DATE	June 13 02	DATE	01745-1	7B

Vert Load 650#

$$\text{Length for stretch} = 1062'$$

$$\text{Cable} = 984 \times 1.76 = 1732\text{ ft}$$

$$\text{Stretch} = (H - 10.824) \frac{1062}{14530} = .073$$

$$\text{Total Wt.} = 2382 \# \quad \frac{1}{2} = 1191$$

SPAN	984'					
Sag DL	19.68					
H DL	10824					
Lgth	985.05					
Wable	1732					
P/W						
Sag LL						
Sag DDL						
H DDL						
H LL						
Stretch	.68	.34				
New Lgth	985.73	985.39				
1/2 Lgth.	492.87	492.67				
defln @	-22.00	-24.00				
Sag (03)	3.25	3.45				
H	16386	15436				
Lgth 1/2	492.55	492.65				
V-	1166	1186				
V+	300	320				
Live load	600	640				
Elod	2382	2372				

Cable S.F.

$$= \frac{81.6}{15.4}$$

$$= 5.3$$



SUBJECT	300m H/D SPAN LOAD + SWAG (500P.S.D) 1"	DESIGN <i>Alastor</i> DATE Oct 30 01	CHECK DATE	JOB NO.	PAGE
---------	--	---	---------------	---------	------

Vert Load = $650 + \frac{500}{2} = 832$ Vert Load. P

Cable weighs $1.76 \times 984 = \frac{1732}{2564}$

Stretch = $(H - 10.824) \times \frac{0.6}{100} + \frac{0.6}{100} = 1/16^{\text{th}}$.

#1

#4

SPAN	984						$H_{D+L} = \frac{(266 + 1732)}{8 \text{ sag}} L$
Sag D.L.	19.68						=
H.D.L	10824						
Lgth	985.05						
W/cable	1732						
P/W	0.48						
Sag L.L.	"						
Sag D.L.	2.16						
Sag D.L.	21.84						
H.D.L	19126			16138			
H.L.L	8302			5314			
Stretch	0.61			0.39			
New Lgth	985.66			985.44			
1/16 th	492.83			492.72			
defln @	22			-25.8			
Sag (03)	2.00			3.30			
H	26627			16138			D.L.
Lgth'	492.51			492.74			Sag = 25.8
1282	V.	1624		1279			
416	V.	758		413			
832	Liv load			826			
2564	Elect			2558			

D.L.
Sag = 25.8
 $\therefore 984 = .026$
2.6%



SUBJECT	300 m Mid Span LOAD + SNOW SLOPES	DESIGN and DATE Dec 14 01	CHECK DATE	JOB NO. 2111 01745-1	PAGE SA
---------	--------------------------------------	------------------------------	---------------	-------------------------	------------

1600# laterally \div 2250 at midspan

$$\therefore H = 24317 \text{ See P.T}$$

$$\begin{aligned} \text{Vert. to Tower} &= 1279 + 24317 \tan 30^\circ \\ &= 15.32 \end{aligned}$$

$$M \text{ to tower } \frac{1600}{2} = 800 \times 33' = 26.4' k$$

$$\text{Load to leg} = \frac{15.32}{2} \pm \frac{26.4}{14.70} = 7.66 \pm 1.80 = 9.46 \text{ or } 5.86$$

$$\text{Comb} = \frac{9.46}{13.17} + \frac{0}{14.82} = 0.72 + 0 = 0.72$$

With Snow $\frac{9.46 + 0.91}{13.17} + \frac{3.17}{14.82} = 0.79 + 0.21 = 1.00$
OK to 10m
tower.

Tension in cable $24317 \text{ vs. } 81.6 = 3.26$

Design Sketch

SUBJECT	300m (984) 1/4 SPAN	DESIGN	22nd	CHECK	JOB NO.	2111	PAGE
Load + SNAG (Scored)	1φ	DATE	May 23 02	DATE	01745-1	88	

$$\text{Vertical load} = 650 + 182 = 832$$

$$\text{Length for stretch} = 984 + 2 \times 39 = 1062'$$

$$\text{Cable} = 1.76 \times 984 = \frac{1732}{2564}$$

$$\text{Str.} = (H - H_d) \frac{1062}{14530} = (H - H_d) .073$$

$$AE = .7854 \times 18500 = 14530 \text{ (21)}$$

SPAN	738			246			Tower :
SAG _{D.L.}	984'						Vat = 1995
	19.68						22.6 ft. = 13.050
H _{D.L.}	10824						14.50 K
L _{gth} _{D.L.}	985.05						= 7.25 / leg.
Waste	1732						1600 ft. c.i. = 1200 ft C Tower
P/W	-						10m Tower
Sag _{L.L.}							M = 1.2 x 33' = 39.6
Sag _{D.L.}							Load / leg =
H _{D+L}							7.25 + $\frac{39.6}{14.7}$ -
H _{L.L.}							= 7.25 + 2.69
Stretch							= 9.94 or 4.56
New L _{gth}							Cable = $\frac{9.94}{13.17} + 0 = 0.75$
1/2 l _{gth}							Draw $\frac{9.94 + 0.91}{13.17} + \frac{3.17}{14.82}$
defl _n (21)	- 21			+ 21			= 0.82 + 0.21 = 1.04 OK.
Sag (23)	8.0			.889			
H	14978			14978			
L _{gth} +	738.53			246.90			H from 8c
V	1076			- 1062			approx. of
V _c	223			1995			H from, sag horizontal
832	Liveload	839					22608
2564	Elod	2571					81600
	EL _{gth}	985.43	ft. = .30 + 985.05 - 985.35				S.F. = 3.6

300m 1/4 Span horiz 1φ



SUBJECT	300m (984) 4 SPAN	DESIGN	Raw	CHECK	JOB NO. 2111	PAGE
Load + Sag (Vert)	1"φ	DATE	May 25, 02	DATE	01745-1	8 C

$$\text{Vert.} = \frac{650}{\text{Eng. Sat.}} = \frac{1600}{2250} \#$$

$$\text{Str.} = (H - H_0) \frac{1062}{14580} = (H - H_0) . 072$$

$$\text{Cable } 1.76 \times 984 = 1732 \\ 3982$$

SPAN	738			246		
SAG _{DL}	984					
	19.68					
H _{DL}	10824					
Lgth	985.05					
Waste	1732					
P/W						
Sag _{LL}						
Sag _{DL}						
H _{DL}						
H _{LL}						
Stretched						
New Lgth						
1/2 Lgth.						
defl ₍₂₎	- 25.5			+25.5		
Sag ₍₃₎	5.3			0.589		
H _{DL}	22608			22608		
Lgth +	738.54			247.32		
V _L	1431			2127		
V _R	-132			2560		
Liveload	2259					
Elod	3991					
Lgth =	985.86			Str. = .86 + 985.05 = 985.91		

Snow OK.

$$\text{Cable S.F.} \\ = \frac{81.6}{22.6} = 3.61$$



Design Sketch

SUBJECT 300m 984' M.D SPAN

LOAD + SNAG (SLOPED) $1\frac{1}{4}^{\phi}$

$$\text{Vert. Load} = 650 + 182 = 832$$

$$\text{Cable weight} 2.75 \times 984 = \frac{2706}{3538}$$

DESIGN
DATECHECK
DATE

JOB NO.

PAGE

9

SPAN	492					
Sag 2L	19.68					
H _{DL}	16913					
L _{gth}	985.05					
Wable	2706					
P/W	.3075					
Sag L.L.	.09					
Sag 2L	1.77					
Sag 2L	21.5					
H _{D+L}		22308				
H _{L.L.}		5395				
Stretch		0.25				
New L _{gth}		985.30				
1/2 L _{gth}		492.65				
defl n @ ①	24		24			
Sag ③	3.73		3.73			
H	22308		22308			
L _{gth} 1/2	492.66					
1769	V _L	1765				
416	V _R	412				
832	Liv load	824				
3538	Eload	3540				

$\Delta + L \text{ Sag}$
 $= \frac{24}{984} = .024$



SUBJECT 300m Mid Span
LOAD + SNAG DROPPED $\frac{1}{4} \phi$

DESIGN Abd
DATE Nov 07 01

CHECK
DATE

JOB NO. 2111
01745-1

PAGE
10

$1600 \text{ # laterally} \div 2250 \text{ at mid span}$ 10m Tower
 $\therefore H = 30592 \quad \text{Sec P. 15}$

$$\begin{aligned}\text{Vert. to tower} &= 1765 + 30592 \tan 30 \\ &= 19.42 \text{ K}\end{aligned}$$

M to Tower $1600/2 = 800$ to Tower top

$$\therefore M = .800 \times 33' = 26.4$$

$$\text{Load to leg} = \frac{19.42}{2} \pm \frac{26.4}{14.70} = 9.71 \pm 1.80 = 11.51 \text{ or } 7.91 \quad \text{10m Tower}$$

$$\text{Comb } \frac{11.51}{13.17} + \frac{0}{14.82} = 0.87$$

$$\underline{\text{With Snow}} \quad \frac{11.51+0.91}{13.17} + \frac{3.17}{14.82} = 0.94 + 0.21 = 1.16$$

\therefore Remove snow from
10m Tower

Tension in CABLE $H = 30592$ for snag dropped.

$$\therefore \text{Tension} = 30.6 \text{ K vs } 141 \text{ K S.F.} = 4.6$$

Try 8m Tower $M = .800 \times 26 = 20.8$ Toly = 11.51 or 7.91-

$$\text{Comb } \frac{11.51+0.91}{20.1} + \frac{3.17}{14.82} = 0.62 + 0.21 = 0.83 \text{ OK.}$$

\therefore Remove snow for 9 + 10m Tower.



SUBJECT 300m (984') 45SPAN
LOAD + VERT. SWAG. $\frac{1}{4} \phi$ "

DESIGN 2nd
DATE Oct 31 01

CHECK
DATE

JOB NO.

PAGE

11

$$\text{Vert Load} = 650 + 1600 = 2250$$

$$300m = 984' = 246 + 738'$$

$$\frac{1}{4} \phi (\text{eff/c}) = 2.75 \text{ plf} \times 984 = 2706 \text{ #}$$

$$L_{\text{for stretch}} = 984 + 2 \times 39 = 1062'$$

$$70.4^{\circ} \text{ B.S.} = 141 \text{ K} \quad A = 1.227$$

$$\text{Str.} = (14 - \frac{1}{100}) \frac{1062'}{22703} = 0.468 \text{ (2)}$$

$$AE = 1.227 \times 18500 = 22703 \text{ (2)}$$

$$\text{Length D} = 985.05$$

 H_{DL}

SPAN	738'			246'			$H = 28803$
Sag DL.	984'						$\text{Str.} = 0.56'$
	19.18						$D_{\text{L/H}} \frac{985.05}{985.61}$
H_{DL}	16913						
Lgth	985.05						
Wable	2706						
P/W	-						
Sag L.L.							
Sag DDL							
H_{DL}							
H_{LL}							
Stretch							
New Lgth							
$\frac{1}{2} \text{ lgth}$							
defln @	23			23			
Sag (03)	6.50		$\div 9 =$	1722			
H	28803			28803			
Lgth @	738.51			247.08			
V_L	1912			-2355			
V_R	117			3031 $\angle 6^{\circ} 00'$			
2250	Live load	2238					
4956	Eload	4943					
	Lgth =	985.59	Str. = 985.61	O.K.			

300m's Sag Vert.

 $\frac{1}{4} \phi$ Tension

$$= 28.8$$

$$vs 141$$

$$S.F. = 4.961$$

Load to Tower

$$3031 + 28803 \tan 30$$

$$= 19.66 \text{ K}$$

$$= 9.83 \text{ K/lag}$$

$$< 13.17 \text{ K}$$

O.K.

Add Snow

$$\frac{9.83 + 0.91}{13.17}$$

$$+ \frac{3.17}{14.82}$$

$$= 0.82 + 0.21$$

$$= 1.03 \text{ O.K.}$$



SUBJECT	300m	1/5SPAN	DESIGN	2001	CHECK	JOB NO.	Z111	PAGE
Load + Vert. Wind.		1/4"	DATE	Nov 08 01	DATE		01745-1	12

Vert to Tower 3031

$$+ 28803 \tan 30 = \frac{16629}{19660}$$

Load per leg : $\div 2 = 9.83 < 13.17$ OK

With Snow

$$\frac{9.83 + 0.91}{13.17} + \frac{3.17}{14.82}$$
$$= 0.82 + 0.21$$

$$= 1.03 \quad \text{O.K.}$$

Tension in CABLE $H = 28803$

Tension = $28.8^kN \times 141 \quad SF = 4.9 \text{ to } 1$

300m 1/5span Snag Bolt 1/4"



SUBJECT	300m (984') $\frac{1}{4}$ SPAN LOAD + SNAG (SLOPED) $\frac{1}{4}\phi$	DESIGN QAW	CHECK	JOB NO.	PAGE
		DATE Oct 31 01	DATE		13

$$\text{Vert Load} = 650 + 182 = 832$$

$$\text{Cable } 2.75 \times 984 \quad \frac{2706}{3538}$$

SPAN	738		246		H = 21275
Sag DL.	984'				Str. $\frac{0-20}{985.05}$
	19.68				$\underline{985.25}$
H DL	16913				
Lgth	985.05				
W cable	2706				
P/W					
Sag L.L.					
Sag DL					
H DL					
H LL					
Stretch					
New lgt					
$\frac{1}{2}$ lgt.					
defl n @	19		19		
Sag (03)	8.80		0.978		
H	21275		21275		
Lgth	738.52		246.74		
V	1562		-1305		
V _R	467		1981		
832	Liv load	838			
3538	Eload	3543			
	EL, th = 985.26	—	Stretched = 985.25		

300 $\frac{1}{4}$ Snag hor.

1/4φ



SUBJECT	300m 4 SPAN Load + SNAG Sealed	DESIGN <i>Asst</i> DATE Nov 07 01	CHECK DATE	JOB NO. 2111 01745-1	PAGE 14
---------	-----------------------------------	--------------------------------------	---------------	-------------------------	------------

$1600 \pm$ laterally $\div 2250$ vertically.

$$\therefore H = 28803 \quad \text{See P. 11}$$

$$\text{Vert to tower} = 1981 + 28803 \tan 30 \\ = 18.61^{\text{k}}$$

FOOTING.

Load to leg = 12.00^k
Do not incl. snow.

$$19 \text{ ft. tower} = 1600 \times \frac{3}{4} \times 33' = 39.6^{\text{in}}$$

$$\text{Load to leg} = \frac{18.61}{2} \pm \frac{39.6}{14.7} \\ = 9.31 \pm 2.69 = 12.00 \text{ or } 6.62$$

$$\text{Comb. } \frac{12.00}{13.17} + \frac{0}{14.82} = 0.91$$

$$\underline{\text{With Snow}} \quad \frac{12.00 + 0.91}{13.17} + \frac{3.17}{14.82} = 0.98 + 0.21 = 1.19$$

$$\underline{9m Tower} \quad \frac{15.9}{20.1} + \quad 0.81 + 0.21 = 1.02$$

$$\underline{8m Tower} \quad \frac{15.9}{20.1} + \quad 0.64 + 0.21 = 0.85$$

\therefore Remove snow for 9m & 10m Towers.

$$\underline{\text{Sway to 8m Tower}} = 0.27 \text{ (P.T-2)} = 0.85 + 0.27 = 1.12 \text{ OK.} \\ < 1.33$$

Tension in CABLE 28.8 kips 141 J.F = 4.9

$$\underline{\text{Load to Tower SHEAVES}} \quad 18.61^{\text{k}} \text{ on } 1\frac{1}{2} \phi \text{ I.S.} = \frac{18.61}{2 \times 1.77} = 5.27 \text{ ksc} \quad \text{OK.}$$

$$\text{Bending} = 18.61^{\text{k}} \rightarrow 9.32 \times \frac{1}{2}^{\text{in}} \text{ say } = 4.7^{\text{in}}$$

$$\text{S.A.} = .331 \quad f_s = 16,2 \text{ ksi - O.K. they bolt.}$$



SUBJECT 300m Mid Span
LOAD + VERT. SNAG 1/4"

DESIGN 221

DATE Nov 1 01

CHECK

DATE

JOB NO.

PAGE

15

$$\text{Vert. load} = 650$$

$$\text{Snag Vert.} \quad 1600$$

$$\frac{1600}{2250} \approx 1125$$

$$\begin{aligned} \text{Lgth per stratch} &= 984 \\ \text{6m Tower} &\quad 2 \times 39 = 78 \\ &\quad \frac{78}{1062} \end{aligned}$$

$$\text{Cable } 2.75 \times 984 = 2706$$

$$\text{Ext. } \frac{2706}{4956} \approx 2478$$

SPAN	984'					
Span 2%	19.68		= .020 Span			
H _{D.L.}	16913					
Lgth	985.05					
Wable	1732					
P/W						
Sag _{D.L.}						
Sag _{D.L.}						
H _{D.L.}	30592					
H _{L.L.}	13679					
Stretch	.64					
New lghth	985.69					
1/2 lghth.	492.84					
defln ₍₂₎	29.0	29.00	= .030 Span = (1.50 D.L Sag)			
Sag ₍₃₎	2.72	2.72				
H	30592	30592				
Lgth _{1/2}	492.89	492.89				
2478	V ₋	2480	2480			
1125	V _R	1127	1127			
2250	Lvls load	2254	2254			
	Eloed	-	-			

$$\begin{aligned} \text{Stretch} &= \frac{(H - H_0) 1062}{18500 \times 1.227} \\ &= (H - H_0) \times 0.0468 \\ &= 985.05 \end{aligned}$$

$$\begin{aligned} \text{Cable S.F.} &= \frac{141}{30.59} = 4.6 \end{aligned}$$

$$\begin{aligned} \text{D.L Sag} &= \frac{29}{984} = .029 \end{aligned}$$



SUBJECT 300m MID SPAN
LOAD + VERT. SNAG 1 $\frac{1}{4}$ "

DESIGN

DATE

CHECK

DATE

JOB NO.

PAGE

15A

$$D.L. Sag = 3\%$$

$$Lgth \text{ for Stretch} = 984 + 2 \times 39 \\ = 1062'$$

$$\text{Vert. Load} = 650 + 1600 = 2250 \quad l_2 = 1125$$

$$\begin{aligned} \text{Stretch} &= \frac{(H - H_0) 1062}{18500 \times 1.227} \\ &= (H - H_0) \times 0.0468 \\ &+ 986.36 \end{aligned}$$

$$\text{Cable } 2.75 \times 984 = \frac{2706}{EWT = 1956} \quad l_2 = 2178$$

SPAN	984				
Sag _{DL}	29.52		= .030 Span		
H _{DL}	11275				
Lgth	986.36				
Wable	2706				
P/W					
Sag _{LL}					
Sag _{DL}					
H _{DL+L}	24546				
H _{LL}	13271				
Stretch	0.62				
New Lgth	986.98				
l ₂ lghth	493.49				
defln @	36.0	36.0	= .037 Span	(1.23 D.L Sag)	
Sag (03)	3.39	3.39			
H	24546	24546			
Lgth' =	493.38	493.38			
V _L	2473	2473			
V _R	1120	1120			
Lvld load	2240	2240			
Eload					

3% D.L Sag.

300m Mid Vert Snag 1 $\frac{1}{4}$ "

Design Sketch

SUBJECT	300m Mid Span LOAD + VERT SWAG. 1 1/4"	DESIGN Alt	CHECK	JOB NO 2111	PAGE
		DATE Nov 08 01	DATE	01745-1	16

$$\begin{aligned}
 \text{Vert to tower} & 2478 = 2.5 \\
 + H \tan 30 & = 30592 = 17.7 \\
 \Sigma & = \underline{\underline{20.1}}
 \end{aligned}$$

$$\text{Load per leg} = \frac{20.1}{2} = 10.1 < 13.17 \text{ OK.}$$

With Snow

$$\begin{aligned}
 & \frac{10.1 + 0.91}{13.17} + \frac{3.17}{14.82} \\
 & = 0.83 + 0.21 \\
 & = 1.05
 \end{aligned}$$

Remove Snow from 10m
OK 9m or less

Tension in CABLE $H = 30592 \text{ vs } 141 = 4.61 \text{ S.F.}$

300 midspan UHSS 1 1/4"



SUBJECT	300 m MARKER	DESIGN <i>read</i> DATE Jan 04 02	CHECK DATE	JOB NO.	PAGE
---------	-----------------	--------------------------------------	---------------	---------	------

984' - 30" of 19# ec. at 45m. = 150' wt = $\frac{19}{150} = 0.13 \text{ plf}$ - Markers

$$3g\phi = 0.25 + 0.13 = 0.38 \text{ plf.}$$

$$H = \frac{0.38 \times 984^2}{8 \times .02 \times 984} = 2317 \text{ ft } T = 2420 \text{ # } \phi .5 = 23600 \\ S.F = 10$$

Add 1" ice =  $A_{ice} = \pi \frac{27.625^2}{4} - \pi \frac{37.5^2}{4} = 5.30 \text{ in}^2$
 $C_{60 \text{ plf}} = 2.21 \text{ plf.}$

On bells  Vol. = $\pi \frac{32^3}{6} - \pi \frac{30^3}{6} = 3000 \text{ in}^3$
 $1.75 \text{ ft}^3/\text{bell}$
 $= 1.75 \times 60/150 = 0.70 \text{ plf.}$

\therefore (Cable + Markers + ice on cable + ice on bells)
 $0.25 + 0.13 + 2.21 + 0.70 = 3.29 \text{ plf.}$

$$H = \frac{3.29 \times 984}{8 \times .02} = 20.2 \text{ ft } T = 21$$

With ice on 1/2" Cable.

Table 2. Summary of Analysis for 300 m Span, 1" Wire Rope, BS = 81,600 lbs.

Loading Condition	Load	H	Cable	A-Frames
(See Section 4.0)	(lbs)	(lbs)	S.F.	(With Snow)
1. $\frac{1}{2}$ span, vertically down	2,250	24,317	3.4	O.K.
2. $\frac{1}{2}$ span with snag load	832	24,317	3.4	O.K.
3. $\frac{1}{4}$ span, vertically down	2,250	22,608	3.6	O.K.
4. $\frac{1}{4}$ span with snag load	832	22,608	3.6	O.K.
5. $\frac{1}{2}$ span no snag load	650	15,436	5.3	O.K.

Table 3. Summary of Analysis for 300 m Span, 1 $\frac{1}{4}$ " Wire Rope, BS = 141,000 lbs.

Loading Condition	Load	H	Cable	A-Frames
(See Section 4)	(lbs)	(lbs)	S.F.	(With Snow)
1. $\frac{1}{2}$ span, vertically down	2,250	30,592	4.6	Remove Snow from 10 m Towers
2. $\frac{1}{2}$ span with snag load	832	30,592	4.6	Remove Snow from 10 m Towers
3. $\frac{1}{4}$ span, vertically down	2,250	28,803	4.9	Remove Snow from 9 & 10 m Towers
4. $\frac{1}{4}$ span with snag load	832	28,803	4.9	Remove Snow from 9 & 10 m Towers
5. $\frac{1}{2}$ span no snag load	650	-	5+	

Table 1. Summary of Analysis for 150 m Span, 1" Wire Rope, BS = 81,600 lbs.


Loading Condition	Load	H	Cable	A-Frames
(See Section 4.0)	(lbs)	(lbs)	S.F.	(With Snow)
1. $\frac{1}{2}$ span, vertically down	2,250	20,020	4.1	O.K.
2. $\frac{1}{2}$ span with snag load	832	20,020	4.1	O.K.
3. $\frac{1}{4}$ span, vertically down	2,250	18,959	4.3	O.K.
4. $\frac{1}{4}$ span with snag load	832	18,959	4.3	O.K.

LOADING SUMMARY

BILLS OF MATERIAL


A COMPLETE 2 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
1	A-FRAME TOP ASSEMBLY	3136-4	CONTRACTOR
1	2 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	1.1 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	CAR HOOK ASSEMBLY LEG	3136-10	CONTRACTOR
2	LADDER BRACKET ASSEMBLY	3136-10	CONTRACTOR
1	3m LADDER	3136-10	* W.S.C.

EST. W.T. 217.0 kg



2 METRE A-FRAME
EXACT HEIGHT TO CENTRE OF 25# WIRE ROPE IN MAIN
CABLE SHEAVE = 2.352 METRES (WITHOUT FOOT PIECE)


3 METRE A-FRAME
EXACT HEIGHT TO CENTRE OF 25# WIRE ROPE IN MAIN
CABLE SHEAVE = 3.332 METRES (WITHOUT FOOT PIECE)



5 METRE A-FRAME
EXACT HEIGHT TO CENTRE OF 25# WIRE ROPE IN MAIN
CABLE SHEAVE = 5.294 METRES (WITHOUT FOOT PIECE)

A COMPLETE 4 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
1	A-FRAME TOP ASSEMBLY	3136-4	CONTRACTOR
1	4 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	1.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	PLATFORM ASSEMBLY	3136-9	CONTRACTOR
1	CAR HOOK ASSEMBLY LEG	3136-10	CONTRACTOR
2	LADDER BRACKET ASSEMBLY	3136-10	CONTRACTOR
1	2m LADDER	3136-10	* OTHER • W.S.C.
1	3m LADDER	3136-10	* W.S.C.

EST. W.T. 265.3 kg



4 METRE A-FRAME SECTION

(THIS SECTION IS TYPICAL OF ALL FRAMES OVER 4 METRES)
EXACT HEIGHT TO CENTRE OF 25# WIRE ROPE IN MAIN
CABLE SHEAVE = 4.313 METRES (WITHOUT FOOT PIECE)

DESIGN LOAD	
2000	4000
2 men	4 men
650 lbs.	1300 lbs.
PLUS SWING LOAD OF 1/8" WIRE ROPE AT ANY ANGLE = 1600 lbs. BREAKING STRENGTH.	

NOTES:

1. ALL PARTS TO BE HOT-DIPPED GALVANIZED C.S.A. G-164.
2. ALL BOLTS & NUTS TO BE M16 AS294 TYPE 2 GALVANIZED.
3. ALL STEEL SHALL CONFORM TO CSA G40.21M GRADE 35W GALVANIZED.

ALL DIMENSIONS IN MILLIMETRES
UNLESS OTHERWISE NOTED

A COMPLETE 1 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:

EST. W.T. 668.0 kg
• WATER SURVEY OF CANADA

QTY	DESCRIPTION	DWG No.	SUPPLIER
1	A-FRAME TOP ASSEMBLY	3136-4	CONTRACTOR
1	1 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	1.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	PLATFORM ASSEMBLY	3136-9	CONTRACTOR
1	CAR HOOK ASSEMBLY LEG	3136-10	CONTRACTOR
4	LADDER BRACKET ASSEMBLY	3136-10	CONTRACTOR
2	3m LADDERS	3136-10	* OTHER • W.S.C.

EST. W.T. 173.4 kg


1	JMF/02	APPROVED AND REDRAWN BY WSC	KON JAW
No.	Date	Revision	Dr. / Cr.

McElhanney
Consulting Services Ltd.
13160 - 98 Ave., Surrey, B.C., Canada V3W 3K3 Telephone (604)596-0391
Vancouver, B.C.

BILLS OF MATERIAL

A COMPLETE 6 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
1	A-FRAME TOP ASSEMBLY	3136-4	CONTRACTOR
1	4 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	2 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	1.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	2.7 METRE HORIZONTAL BRACE ASSEMBLY	3136-8	CONTRACTOR
1	PLATFORM ASSEMBLY	3136-9	CONTRACTOR
1	CAR HOOK ASSEMBLY LEG	3136-10	CONTRACTOR
4	LADDER BRACKET ASSEMBLY	3136-10	CONTRACTOR
1	4m LADDER	3136-10	• OTHER W.S.C.

EST. W.T. 718.1 kg



A COMPLETE 8 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
1	A-FRAME TOP ASSEMBLY	3136-4	CONTRACTOR
2	4 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	1.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	3.1 METRE HORIZONTAL BRACE ASSEMBLY	3136-8	CONTRACTOR
1	PLATFORM ASSEMBLY	3136-9	CONTRACTOR
1	CAR HOOK ASSEMBLY LEG	3136-10	CONTRACTOR
4	LADDER BRACKET ASSEMBLY	3136-10	CONTRACTOR
2	4m LADDERS	3136-10	• OTHER W.S.C.

EST. W.T. 763.6 kg

1. ALL PARTS TO BE HOT-DIPPED GALVANIZED C.S.A. G-164.
2. ALL BOLTS & NUTS TO BE M16 A22SM TYPE 2 GALVANIZED.
3. ALL STEEL SHALL CONFORM TO C.S.A. G40.21M GRADE 350W GALVANIZED.

NOTES:

EST. W.T. 811.3 kg
WATER SURVEY OF CANADA

ALL DIMENSIONS IN MILLIMETRES
UNLESS OTHERWISE NOTED

1 JUN/02	APPROVED AND REDRAWN BY MCSC	NON APP
No Date	Revision	Dr Ch

McElhanney Consulting Services Ltd.
13180-88 Ave., Surrey, B.C., Canada V3W 3K3 Telephone (604)586-0391

DESIGN LOAD

CAR	200
2 MEI	400
REEL	500
PLUS SWING LOAD OF 1/8 ^o WIRE ROPE AT ANY ANGLE = 1610 lbs. BREAKING STRENGTH.	650 lbs.

A COMPLETE 6 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
1	A-FRAME TOP ASSEMBLY	3136-4	CONTRACTOR
1	4 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	2 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	1.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	1.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	CAR HOOK ASSEMBLY LEG	3136-10	CONTRACTOR
6	LADDER BRACKET ASSEMBLY	3136-10	CONTRACTOR
3	3m LADDERS	3136-10	• OTHER W.S.C.

EST. W.T. 811.3 kg
WATER SURVEY OF CANADA

ALL DIMENSIONS IN MILLIMETRES
UNLESS OTHERWISE NOTED

BILLS OF MATERIAL

A COMPLETE 9 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
1	A-FRAME TOP ASSEMBLY	3136-4	CONTRACTOR
1	4 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	2 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	3 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	1.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	2.7 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	3.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	LATERAL BRACING ASSEMBLY FOR 9 METRE A-FRAME	3136-6	CONTRACTOR
1	PLATFORM ASSEMBLY	3136-9	CONTRACTOR
1	CAR HOOK ASSEMBLY LEG	3136-10	CONTRACTOR
6	LADDER BRACKET ASSEMBLY	3136-10	CONTRACTOR
1	4m LADDER	3136-10	• OTHER W.S.C.
2	3m LADDERS	3136-10	• OTHER W.S.C.



EST. W.T. 980.7 kg
WATER SURVEY OF CANADA

A COMPLETE 10 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:

QTY	DESCRIPTION	DWG No.	SUPPLIER
1	A-FRAME TOP ASSEMBLY	3136-4	CONTRACTOR
1	4 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
2	3 METRE LEG ASSEMBLY	3136-5	CONTRACTOR
1	1.9 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	3.1 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	4.2 METRE HORIZONTAL BRACE ASSEMBLY	3136-6	CONTRACTOR
1	LATERAL BRACING ASSEMBLY FOR 10 METRE A-FRAME	3136-6	CONTRACTOR
1	PLATFORM ASSEMBLY	3136-9	CONTRACTOR
1	CAR HOOK ASSEMBLY LEG	3136-10	CONTRACTOR
6	LADDER BRACKET ASSEMBLY	3136-10	CONTRACTOR
1	4m LADDER	3136-10	• OTHER W.S.C.
2	3m LADDERS	3136-10	• OTHER W.S.C.

EST. W.T. 1056.9 kg
WATER SURVEY OF CANADA

A COMPLETE 9 METRE A-FRAME ASSEMBLY CONSISTS OF THE FOLLOWING:



DEPT. OF THE ENVIRONMENT
WATER SURVEY OF CANADA, VANCOUVER, B.C.

DESIGN LOAD	CAB 2000 lbs. 2 MEN 400 lbs. REEL 800 lbs.
PLUS SWAG LOAD OF 1/8" WIRE ROPE AT ANY ANGLE = 160 lbs. BREAKING STRENGTH.	

ALL DIMENSIONS IN MILLIMETRES
UNLESS OTHERWISE NOTED

- NOTES:
1. ALL PARTS TO BE HOT-DIPPED GALVANIZED C.S.A. G-184.
2. ALL BOLTS & NUTS TO BE M16 A22M TYPE 2 GALVANIZED.
3. ALL STEEL SHALL CONFORM TO C.S.A. G40.21M GRADE 35W GALVANIZED


1 ANNE /02	APPROVED AND REDRAWN BY MCSE	KEN ANN
Revision		Dr Ch
Date		Approved


DEPT. OF THE ENVIRONMENT
WATER SURVEY OF CANADA, VANCOUVER, B.C.
HEAVY DUTY A-FRAMES
9 & 10 METRES
VANCOUVER, B.C.

Designed D.O.E. Job No. 2111-01745-1 Drawing No.
Drew K.D.W. Scale 1:25
Checked A.A.W. Date APRIL 2002
Approved Revision 1 of 10

ALL DIMENSIONS IN MILLIMETRES
UNLESS OTHERWISE NOTEDA-FRAME TOP
SCALE 1:4FRONT VIEW
A-FRAME TOP
SIDE VIEW
A-FRAME TOP
DETAIL 4
SCALE 1:2
BACK STAY EYEBOLT
SECTION A-ADEPT. OF THE ENVIRONMENT
WATER SURVEY OF CANADA, VANCOUVER, B.C.HEAVY DUTY A-FRAMES
VARIOUS DETAILS, TOP ASSEMBLY


VANCOUVER, B.C.

MAIN CABLE SHEAVE BRACKET
DETAIL 3
SCALE 1:2
FRONT
SIDE
BACKDESIGNED BY
K.D.W.
CHECKED BY
C.H.W.
APPROVED
BY
Dr. Ch.DRAWING NO.
3136-4
REV. 1
JULY 2002DRAFTING NO.
10



W.T. 100x15.5
(CUT FLANGE TO SUIT
DIMENSIONS SHOWN)

EST. W.T. 187.4 KG



EST. W.T. 101.5 KG

A COMPLETE 3 METRE LEG ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
2	3 METRE LEG	3136-5	FABRICATOR
16	BOLTS M16x60 A325 c/w NUT & WASHER	FABRICATOR	

EST. W.T. 144.7 KG

A COMPLETE 2 METRE LEG ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
2	1 METRE LEG	3136-5	FABRICATOR
16	BOLTS M16x60 A325 c/w NUT & WASHER	FABRICATOR	

EST. W.T. 70.6 KG


A COMPLETE 1 METRE LEG ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
2	1 METRE LEG	3136-5	FABRICATOR
16	BOLTS M16x60 A325 c/w NUT & WASHER	FABRICATOR	

A COMPLETE 1 METRE LEG ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG No.	SUPPLIER
2	1 METRE LEG	3136-5	FABRICATOR
16	BOLTS M16x60 A325 c/w NUT & WASHER	FABRICATOR	


EST. W.T. 70.6 KG

- NOTES:
 1. ALL PARTS TO BE HOT-DIPPED GALVANIZED.
 2. ALL BOLTS & NUTS TO BE A325M TYPE 2 GALVANIZED, UNLESS
 NOTED OTHERWISE.
 3. ALL STEEL SHALL CONFORM TO CSA G40.21M GRADE 350W.

* ALL LEG ASSEMBLIES ARE TO BE MADE
UP OF A SINGLE PIECE OF HSS
127x127x4.78, NO WELDED JOINT.



EST. W.T. 70.6 KG



EST. W.T. 70.6 KG

BILLS OF MATERIAL

ALL DIMENSIONS IN MILLIMETRES
UNLESS OTHERWISE NOTED

DEPT. OF THE ENVIRONMENT WATER SURVEY OF CANADA, VANCOUVER, B.C.	APPROVED AND DRAWN BY MCSL K.D.W. Checkpt A.A.M. Dated April 2002 Approved Revision 1	Designed D.O.E. Drawn K.D.W. Scale AS SHOWN Date APR. 2002 Approved Revision 1	Job No. 2111-01745-1 Drawing No. 3136-5 13180-88 Ave., Surrey, B.C., Canada V3W 3K3 Telephone (604)596-0391 VANCOUVER, B.C.
---	--	---	---

A COMPLETE LATERAL BRACING ASSEMBLY CONSISTS OF THE FOLLOWING:			
QTY	DESCRIPTION	DWG. NO.	SUPPLIER

<tbl_r cells="4" ix="2" maxcspan="1"