



**FLOOR PLAN**  
SCALE: 1:100

KEY NOTES	
1	INSTALL NEW BOILERS C-B1 & C-B2 C/W ALL ACCESSORIES (LOW WATER CUT-OFF, FLOW SWITCH, PRESSURE RELIEF) AND CONNECT TO CHIMNEY, HWS/HWR LINE & GAS. RECONNECT TO BUILDING CONTROL SYSTEM.
GENERAL NOTES	
1	CONTRACTOR IS RESPONSIBLE FOR ALL PERMITS.
2	CONTRACTOR TO ENSURE ALL WORK COMPLIES WITH AUTHORITY HAVING JURISDICTION.
3	NATURAL GAS PRESSURE IN BUILDING IS 35 KPa.
4	ALL HEATING WATER SUPPLY AND RETURN PIPE SIZES TO BE 20" UNLESS OTHERWISE NOTED.
5	BOILER GAS DEMAND 8.92 M³/HR EACH.
6	CONTRACTOR TO VERIFY EXISTING UNITS' POWER REQUIREMENT PRIOR TO ORDER OF NEW UNITS AND TO ENSURE NEW UNITS DO MATCH VOLTAGE AND PHASE AND DO NOT EXCEED EXISTING AMP DRAW REQUIREMENTS. CONTRACTOR TO RECONNECT ALL NEW UNITS TO EXISTING ELECTRICAL AND TO REPAIR/REPLACE DAMAGED CONDUITE, WIRING, JUNCTION BOXES AND OTHER ELECTRICAL DAMAGED DURING DEMOLITION AND INSTALL OF NEW EQUIPMENT WITH SAME THAN ORIGINAL.
7	RECONNECT EXISTING DDC HVAC CONTROL SYSTEM TO NEW UNITS AS PER ORIGINAL. PERFORM ALL NECESSARY CHECKS TO ENSURE IT OPERATES CORRECTLY AS PER PRE-DEMOLITION INSTALL.



**EAST MECHANICAL ROOM FLOOR PLAN**  
SCALE: 1:50



#		
#		
#		
2	ISSUED FOR TENDER	16/09/07
1	ISSUED FOR 95% REVIEW	16/05/30
0	ISSUED FOR 60% REVIEW	15/10/10
Revision/	Description/Description	Date/Date
Revision/		

Client/client  
**PUBLIC WORKS AND GOVERNMENT SERVICES CANADA**

Project title/Titre du projet  
**Pê Sâkâstêw Centre  
Maskwacis, Alberta**  
**Pê Sâkâstêw Centre  
REPLACEMENT OF  
ROOFTOP UNITS BOILERS**

Approved by/Approuvé par  
**GBB**  
Designed by/Concept par  
**HFB**  
Drawn by/Dessiné par  
**HFB**  
PWGSC Project Manager/Administrateur de Projets TFSGC  
**STEVE PHYBERS**  
PWGSC, Architectural and Engineering Resources Manager/  
Ressources Architectural et de Directeur d'ingénierie, TFSGC  
Client/client  
**PWGSC**

Drawing title/Titre du dessin  
**BUILDING C - BOILERS  
CONSTRUCTION PLAN**

Project No./No. du projet <b>R.077183.00</b>	Sheet/Feuille <b>M1.1</b> OF 16	Revision no./ La Révision no. <b>2</b>
---	---------------------------------------	--