

Part 1 General

1.1 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for electric and electronic control system for HVAC and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

1.2 DELIVERY, STORAGE AND HANDLING

- .1 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .2 Storage and Handling Requirements:
 - .1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect electric and electronic control systems from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 THERMOSTAT (LOW VOLTAGE)

- .1 Low voltage wall thermostat:
 - .1 For use on 24 V circuit at 1.5 A capacity.
 - .2 With heat anticipator adjustable 0.1 to 1.2 A.
 - .3 Temperature setting range: 10 degrees C to 25 degrees C.
 - .4 Without sub-base.

2.2 LOW LIMIT TEMPERATURE ALARM

- .1 Low limit temperature alarm with:
 - .1 Rating: 10.2 A at 120 V.
 - .2 Sensing bulb and 1.5 m long capillary tube.
 - .3 Switching action: manual.
 - .4 Temperature setting range: 0 degrees C to 15 degrees C.

2.3 HIGH LIMIT TEMPERATURE ALARM

- .1 High limit temperature alarm with:

- .1 Rating 10 A at 120 V.
- .2 Positive lock-out.
- .3 Manual reset only after 14 degrees C drop-in temperature.
- .4 Cut-out setting: 50 degrees C.

2.4 FLOW SWITCH

- .1 Flow switch for to match boiler flow capacity, pipe size as indicated, CSA Enclosure, rated at 16 A at 120 V. Maximum liquid temperature: 121 degrees C. Maximum liquid gauge pressure of 1034 kPa ambient temperature range 0 degrees C to 82 degrees C.

2.5 PRESSURE SWITCH

- .1 Pressure switch for water at range 0 to gauge pressure of 1034 kPa with auto manual reset, contacts open on rise. Maximum allowable gauge pressure of 1.2 MPa. Full load 16 A at 120 V, ULC rated.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for electric and electronic control systems installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied.

3.2 INSTALLATION

- .1 Install control devices.
- .2 On outside wall, mount thermostats on bracket or insulated pad 25 mm from exterior wall.
- .3 Install remote sensing device and capillary tube in metallic conduit. Conduit enclosing capillary tube must not touch heater or heating cable.

3.3 CLEANING

- .1 Progress Cleaning: Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.

END OF SECTION