

Client/client

Project title/Titre du projet

Pê Sâkâstêw Centre REPLACEMENT OF ROOFTOP UNITS BOILERS

Designed by/Concept par

Drawn by/Dessiné par
JEB

STEVE PHYPERS

ressources Architectural et de Directeur d'Ingénierie, IPSCC

PWGSC

BUILDING E - BOILERS

Figure 1

Proj	MD 9	Ed Revision no.
------	------	-----------------

	OF 16	
--	-------	--



1 MAIN FLOOR PLAN
M2.0 1:150

GENERAL NOTES	
1	CONTRACTOR IS RESPONSIBLE FOR ALL PERMITS.
2	CONTRACTOR TO ENSURE ALL WORK COMPLIES WITH AUTHORITY HAVING JURISDICTION.
3	MAIN BOILER FLUE: 400%.
4	E-B1 & E-B2 GAS DEMAND EACH: 20.4 M ³ /HR.
5	CONTRACTOR TO RETAIN ELECTRICAL FOR RECONNECTION.