



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Concrete Apron Regrading	
Solicitation No. - N° de l'invitation EZ899-181746/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2017-12-06
GETS Reference No. - N° de référence de SEAG PW-\$PWY-025-8229	
File No. - N° de dossier PWY-7-40265 (025)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-12-12	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Fung, Donna(PWY)	Buyer Id - Id de l'acheteur pwy025
Telephone No. - N° de téléphone (604) 671-9689 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CBSA - Pacific Highway POE - Surrey, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

This Amendment 002 is raised to

- 1) incorporate Addendum 002, and
- 2) provide the list of Site Visit attendees

Please see the attached Addendum 002.

Site Visit Attendees

Deramore Construction Services Inc., Abbotsford

Effort Global Construction Inc., North Vancouver

Fricia Construction Inc., Abbotsford

Nations Construction & Consulting, Agassiz

Neelco Builders Ltd., Chilliwack

Potential bidders are reminded that they are NOT to visit the site unexpectedly. Any and all visitors will be asked to leave.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Requisition No. EZ899-181746/A

The following changes in the tender documents are effective immediately. This addendum will form part of the Contract documents.

Answers (A) to Questions/Requests (Q) Received:

- Q.1 There is a note on Dwg 4, Point 1, under the FOUNDATION heading.
“...contractor to hire geotechnical engineer to confirm bearing pressure...” Is there a Geotechnical Engineer that PWGSC would prefer to be used?
- A.1 *No. The Contractor is free to choose their Geotechnical Engineer, who is required to be a licensed P.Eng. with Engineers and Geoscientists BC (formerly APEGBC).*
- Q.2 We also note there is a Dept/PWGSC Geotechnical Engineer for testing on dwg 4, Point 2, under the BACKFILL AND COMPACTION heading. Can these 2x Geotechnical Engineers be the same person/company?
- A.2 *The Base and Sub-base approval is to be provided by the same Geotechnical Engineer that confirms the foundation bearing pressures, and is to be retained by the Contractor.*
- Q.3 The tender documents call for the existing Granular Base to be removed. Do you know what the existing Granular Base material is? Can it be stockpiled on site and re-used under the new SOG?
- A.3 *Bidders are to include for new base and sub-base material, as per the tender documents. Re-use of existing material may or may not be considered during construction.*

END OF ADDENDUM