



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**

**Bid Receiving - PWGSC**  
**ATB Place North Tower**  
**10025 Jasper Ave NW**  
**Edmonton**  
**Alberta**  
**T5J 1S6**  
**Bid Fax: (780) 497-3510**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada/Travaux  
publics et Services gouvernementaux Canada  
Suite 1650  
635 - 8th Ave. S.W.  
Bureau 1650  
635 - 8e avenue, SO  
Calgary  
Calgary  
Alberta  
T2P 3M3

<b>Title - Sujet</b> C5-09 Stope Stabilization	
<b>Solicitation No. - N° de l'invitation</b> EW702-173131/B	<b>Amendment No. - N° modif.</b> 009
<b>Client Reference No. - N° de référence du client</b> INAC-EW702-173131	<b>Date</b> 2017-12-07
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$GMP-015-6655	
<b>File No. - N° de dossier</b> GMP-7-40055 (015)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-12-15</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Standard Time MST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Bilous, Isabelle	<b>Buyer Id - Id de l'acheteur</b> gmp015
<b>Telephone No. - N° de téléphone</b> (780) 782-8714 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**This amendment 009 is raised to modify solicitation EW702-173131/B as follows:**

**1. Questions and Answers**

**Question 67:** Section 01 31 19: Are all Weekly/Monthly meeting attendees required to attend in person, or can some phone in if necessary?

**Answer 67:** Yes, attendees can phone in if necessary.

**Question 68:** Section 31 72 00: In 1.7.2, it indicates that Ground Support work is to be paid "by the lineal metre of installed ground support in the Back of the drifts and intersections". Please confirm whether this is lineal metres of bolt installed or lineal metres of roof supported.

**Answer 68:** Tracking and reporting for payment of lineal metres of bolts or mesh will not be measured as part of this contract. Instead payment item 31 72 00 – 1 (in 1.7.2) is for lineal metres of supported Back and includes all bolts, face plates, nuts and screen.

**Question 69:** Section 31 05 16 does not include any gradation for granular mater for items listed in 1.1.1; can the Contractor use any gradation fit for purpose? Are there any gradation specifications for the aggregate to be used in the self-levelling concrete?

**Answer 69:** The contractor is permitted to use a gradation of materials that would typically be intended for that purpose. As aggregate pertains to the self-levelling concrete, the only requirement (section 03 30 00.09 clause 2.2.1.2.3) is that the aggregate size is less than 19 mm.

**Question 70:** Drawing C05r1 indicates that the self-levelling concrete slump be 600mm +/- 20mm. This is a narrower range than normally seen; can this be increased to 600mm +/- 80mm or more?

**Answer 70:** Please refer to Section 03 30 00.09 clause 2.2.1.1.2 – "maximum slump for each design of 675 mm". Drawing C05R1 will be revised to be consistent with section and provided upon award of the contract.

**Question 71:** The existing information on boreholes provided by Golder is missing much needed clarity on the table in terms of descriptions and headers for this key table. Can you please provide?

**Answer 71:** Refer to revised table at ATT003.

**Question 72:** Can you provide clarification on Question 8 (issued in amendment 004) and confirm definition of named individuals that can't be used across multiple projects?

**Answer 72:** Further to Question 8, a contractor forming part of a proposed Main Construction Manager (MCM) Core Team would not be in a position of conflict of interest and would not be precluded from bidding on C5-09. As noted in Question/Answer 9, the work under the C5-09 contract will remain separate from the MCM and will be managed by PSPC. Because of this, the conflict of interest that would exist if the MCM were managing a Work Package performed by their own forces is not applicable to the C5-09 project.

In accordance with **SI07 Status and Availability of Resources**, the Bidder certifies that, should it be awarded a contract as a result of the bid solicitation, every individual proposed in its bid will be available to perform the Work as required by Canada's representatives. The Key Individuals who will be required to be dedicated to this project are **Project/Site Superintendent** and **Paste/Concrete Production and Placement Supervisor**. During underground work activities, the **Underground Works Supervisor** will also be required to be dedicated to this project. All other positions are still required to be available to perform the Work as required by Canada's representatives.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**