



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving -
PWGSC

1550, Avenue d'Estimauville

1550, D'Estimauville Avenue

Québec

Québec

G1J 0C7

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

TPSGC-PWGSC

601-1550, Avenue d'Estimauville

Québec

Québec

G1J 0C7

Title - Sujet Reconstruction quai Grande-Entrée	
Solicitation No. - N° de l'invitation F3731-170016/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client F3731-170016	Date 2017-12-08
GETS Reference No. - N° de référence de SEAG PW-\$QCM-008-17263	
File No. - N° de dossier QCM-7-40165 (008)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-12-13	Time Zone Fuseau horaire Heure Normale du l'Est HNE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Rochette, Jean	Buyer Id - Id de l'acheteur qcm008
Telephone No. - N° de téléphone (418) 649-2834 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

AMENDEMENT 005

Title: THE DEMOLITION AND RECONSTRUCTION OF WHARVES 401 TO 405 OF THE FISHING HARBOUR OF GRANDE-ENTRÉE IN THE MAGDALEN ISLANDS, QC

Included in the present amendment:

1. Questions and answers 55 to 62
-

QUESTIONS AND ANSWERS:

Question 55: Is it possible to breakdown the 451 MT (Item 2.2 of the tender form) of contaminated material disposition as this item includes existing timber wharves, granular materials and dredging material?

Answer 55: his Item includes only treated wood from the demolition of the existing wharves. Contaminated sediments from dredging work under wharves to be demolished are stored on the site between watertight geotextile.

Question 56: Please confirm that the wood disposal from wharves demolition will be paid according to Item 2.2 of the tender form.

Answer 56: Yes.

Question 57: Can you tell us if the piles of the 3 wharves can be cut at sea bottom or it is necessary to completely extract them?

Answer 57: The wooden piles are to be completely extracted.

Question 58: Regarding precast slabs to recover, could we know what will be the future use of these slabs? Knowing their use, we could plan a more efficient method to extract them (with or without damage).

Answer 58: Departmental Representative could use these slabs to repair existing structures or build a rolling surface that is currently made of crushed stone.

Question 59: Can you tell us the type of allowed vehicle on the existing spur wharfs, is it mentioned "light vehicle"?

Answer 59: It is a vehicle weighing less than 3,600 kg of pickup type. Departmental Representative do not have a structural study to point out the actual bearing capacity of the structure.

Question 60: Do we have to allow the dredging material to settle before being placed on the DFO field, or can we decant directly into the DFO field?

Answer 60: The usual procedure is to settle on the wharf prior to sediment loading.

Question 61: If settling is necessary, should we recover leachate?

Answer 61: The usual procedure is to settle on the wharf prior to sediment loading.

Question 62: Is there a characterization of the dredging material to be done?

Answer 62: No.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.