

GENERAL

The following changes in the Tender Documents are effective IMMEDIATELY. This addendum will form part of the Contract Documents

DRAWINGS

None

SPECIFICATIONS

None

CLARIFICATIONS

None

QUESTIONS

Question 1:

Is there information on the existing concrete piles that need to be removed? Size, depth, etc.

Answer 1:

The anchors are corrugated metal pipes filled with concrete. Six anchors are 914 mm diameter and 914 mm high. One anchor is 914 mm diameter and 1220 mm high.

END OF ADDENDUM 2