

# Addendum / Addenda

Project Description / Description de projet <b>M19 Stores Amalgamation Phase 1</b>		
Solicitation No./N° de sollicitation <b>17-22098</b>	Project No./N° de projet <b>5463</b>	W.O. No./N° d'ordre de travail <b>A1-009908/99</b>
Departmental Representative / représentant ministériel <b>Janik Leroux</b>		Date <b>December 12, 2017</b>
<p><b>Notice:</b> This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p><b>Nota:</b> Cet addenda fait partie intégrale des dossiers d'appel; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

**GENERAL**

Questions for bidders:

1. Can you please confirm who are we to use for Fire Alarm Bypass and Sprinkler work for the project noted above.

**Answer:** Any licenced contractor can perform the sprinkler work. The fire alarm bypass is performed by NRC internal Electricians.

2. What is the level of clearance required to work at this site? Would Police check be acceptable?

**Answer:** As stated in our specification document, under BuyandSell section 5.2.2, the general contractor and all his sub-contractors must hold a valid Reliability Status, granted or approved by CISD/PWGSC, or any other Federal Department or Agency along with the names and birthdates or security clearance certificate numbers of all personnel who will be assigned to the project.

**ARCHITECTURAL**

ON DRAWING 5463-A00, PARTITION WALLS: NEW CONSTRUCTION.

REVISE WALL TYPES AS FOLLOWS:

**W-1 NEW INTERIOR PARTITION**

· 13mm GYPSUM BOARD, TO 150mm ABOVE ACT, PAINT FINISH.

**REMOVE** - ~~64mm, 20ga METAL STUDS At 400mm O.C., EXTEND TO 150mm ABOVE ACT.~~

**ADD** - 92mm, 20ga METAL STUDS At 400mm O.C., EXTEND TO U/S OF STRUCTURE

**ADD** - FILL VOIDS WITH ROXUL SAFE N SOUND.

· EXISTING PLASTER AND TERRA COTTA TILE WALL.

NOTES:

1.) GYPSUM BOARD TO EXTEND A 150mm ABOVE ACT.

2.) C/W METAL CHANNEL STIFFENERS.

**W-3 NEW WALL FINISH**

ADD

ADD

REMOVE

- 13mm GYPSUM BOARD, TO 150mm ABOVE ACT, PAINT FINISH.
- 92mm, 20ga METAL STUDS At 400mm O.C., EXTEND TO U/S OF STEEL STRUCTURE.
- FILL VOIDS WITH ROXUL SAFE N SOUND.
- ~~EXISTING METAL STUDS ADD STUDS OR MODIFY AS REQUIRED. — EXTEND TO 150mm~~  
ABOVE ACT.

