



Parks Canada  
Parcs Canada



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada  
National Contracting Services**

**3, passage du Chien-d'Or  
Quebec, QC  
G1R 3Z8**

INVITATION TO TENDER  
APPEL D'OFFRES

## AMENDMENT #4 TO:

### Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

### Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

### Comments – Commentaires

### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### Issuing Office - Bureau de distribution

Parks Canada Agency  
3, passage du Chien-d'Or  
Quebec, QC, G1R 3Z8

Title-Sujet <b>Administration heating and hot water upgrade/ Kejimikujik national Park</b>		Date <b>2017.12.14</b>
Solicitation No. - No. de l'invitation <b>5P201-17-5132/A</b>		Client Ref. No. - No. de réf du client.
GETS Reference No. - No de reference de SEAG		
Solicitation Closes L'invitation prend fin –  <b>at – à 2:00 PM on – le 2017-12-19</b>		Time Zone Fuseau horaire - <b>EASTERN STANDARD TIME (EST)</b>
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à :  Sylvie Lagacé <a href="mailto:sylvie.lagace@pc.qc.ca">sylvie.lagace@pc.qc.ca</a>		
Telephone No. - No de téléphone <b>418-648-5006</b>		Fax No. - No de FAX: <b>418-649-6971</b>
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:  <b>See Herein</b>		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur  Telephone No. - No de telephone: _____ Facsimile No. - N° de télécopieur: _____		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur  _____ Name / Nom Title / Titre  _____ Signature Date		



## AMENDMENT #4

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE UPDATES TO THE DRAWINGS AND SPECIFICATIONS AND TO ANSWER QUESTIONS RECEIVED BY POTENTIAL BIDDERS.

You must considered this information in the evaluation of you bid.

See document Propane Water and submittal in the tender attachments:  
**TRINITY LX200WH SUBMITTAL**

### QUESTIONS & ANSWERS:


We received addendum 2. There is still info that we requested that is missing:

Q1. Spec on propane water heater.

R1. See attached NTI Trinity LX200WH Propane Water and submittal.

Q2. Location that solar panels are to be installed.

R2. Solar to be installed on the SSW portion of the roof (i.e. back left corner if you are look at the front of the building from the parking lot). Install should consider the tree line on the left hand side of the building, and push right as far as it needs to be to avoid shading. I've attached a picture from Google Maps for quick reference.



Q3. Where new propane tanks are to be installed and what size is required?



R3. Propane tanks to be installed at the rear of the building near the existing boiler room. A single 120 gallon/420 lb would be enough for the relatively low hot water load, but if they are concerned with extended power outages and road closure then 2 x 120 gal would make sense.

Q4. Do the revised drawings supersede the original? The consultant has removed drawing M-02 in the new set.

R4. The new drawings supersede the old with the exception of M-02 for the solar, which was not changed.

**There is no change to the tender closing date.**

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.**

---

**Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.  
Fax: 418 649-6971.**