



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Health Care Expansion	
<b>Solicitation No. - N° de l'invitation</b> EZ899-181607/A	<b>Amendment No. - N° modif.</b> 007
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2017-12-18
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-025-8228	
<b>File No. - N° de dossier</b> PWY-7-40258 (025)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-12-22</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Fung, Donna(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy025
<b>Telephone No. - N° de téléphone</b> (604) 671-9689 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> CSC - Mountain Institution - Agassiz, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-181607/A  
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.  
007  
File No. - N° du dossier  
PWY-7-70258

Buyer ID - Id de l'acheteur  
PWY025  
Project No.- No. du projet  
R.077724.001

---

This Amendment No. 007 is raised to incorporate Addendum #04.

Please see the attached Addendum #04.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

---

## **DRAWINGS**

- .1 P-2 RENOVATION EXISTING BUILDING MAIN FLOOR PLAN PLUMBING
    - a) **[Clarification]** refer to the “Existing Mechanical Rm. – Plumbing” partial floor plan on plumbing drawing P-2. The existing 25mm gas riser in the existing Mechanical Room in the Mezzanine has a capacity of 18.54 cubic metres per hour. (*Difficult to read on prints.*)
  - .2 P-5 DETAILS PLUMBING
    - a) **[ADD]** refer to the “Domestic Hot Water Tank With Recirculating Pump” detail on plumbing drawing P-5. The electric domestic hot water heater tank DHWT-1 add wording: “shall be a nominal 189 litres (50 USgal) with 6 kW power input at 600 V / 3 Ph.”
-